

Fault Detection and Isolation based on the Combination of a Bank of Interval Observers and Invariant Sets

Feng Xu, Florin Stoican, Vicenç Puig, Carlos Ocampo-Martinez and Sorin Oлару

Abstract—In this paper, a fault detection and isolation (FDI) approach using a bank of interval observers is developed. From the methodological point of view, a bank of interval observers is designed according to different dynamical models of the system under different modes (healthy or faulty). Each interval observer matches one system mode while all the interval observers monitor the system simultaneously. In order to guarantee FDI, a set of FDI conditions based on invariant set notions are established. These conditions ensure that the considered faults can be accurately isolated after a period of monitoring time. Finally, simulation results are used to present the effectiveness of the approach.

I. INTRODUCTION

According to the recent literature [2], [3], [5], interval observers have been successfully used for fault detection (FD) purposes, but not for fault isolation (FI) purposes. The aim of this present paper is to extend the use of interval observers to fault isolation (FI).

The interval observer-based FD approach consists in propagating the effect of uncertainties by means of the system mathematical models to generate adaptive thresholds for residuals. Then, the FD is performed by testing the consistency between model predictions and current measurements of the corresponding residuals [2], [5].

The interval observer-based FD approach consists in propagating the effect of uncertainties by means of the system mathematical models to generate adaptive thresholds for residuals. Then, the FD is performed by testing the consistency between model predictions and current measurements of the corresponding residuals [2], [5].

Whatever mode the system is under, an interval observer consistent with the current mode model of the system always predicts state or output interval vectors that confine the current system states or outputs at each time instant. This mechanism provides useful information to detect and isolate faults when a bank of interval observers is used.

An FDI approach based on a bank of set-valued observers—different from interval observers—is proposed in [6]. Under a set of assumptions regarding the system, that proposed approach can implement FDI scheme. However, comparatively, the approach proposed in this paper provides a set of definite and pre-checkable FDI conditions that allow to know a priori whether faults are detectable and isolable.

Considering the good balance among expressional compactness, computational precision and complexity offered by zonotopes [1], this paper focuses on the representation

F. Xu, V. Puig and C. Ocampo-Martinez are with the Institut de Robòtica i Informàtica Industrial (CSIC-UPC), Technical University of Catalonia, Llorens i Artigas, 4-6, 08028 Barcelona, Spain, {fxu, vpuig, cocampo}@iri.upc.edu.

F. Stoican is with the Politehnica University of Bucharest (PUB) - Department of Automatic Control and Systems Engineering, Bucharest, Romania, florin.stoican@acse.pub.ro.

S. Oлару is with the E3S (SUPELEC Systems Sciences), Automatic Control Department, Gif sur Yvette, France, sorin.olaru@supelec.fr.

of uncertainties by zonotopes and the design of interval observers based on the Luenberger structure.

The contribution of this paper is twofold. First, it extends interval observer-based approaches to the case of FI, which implies that interval observers can independently implement FDI without the help of other FI techniques such as the fault signature matrices. Second, it establishes a set of FDI conditions to guarantee interval observer-based FDI.

The remainder of this paper is organized as follows. Section II introduces the notions of zonotopes and invariant sets. Section III introduces the plant and interval observers. The FDI algorithm is presented in Section IV. In Section V, guaranteed FDI conditions are established. An extension of the approach for sensor faults is briefly discussed in Section VI. In Section VII, the examples are used to show the effectiveness of the proposed approach. In Section VIII, general conclusions are drawn.

II. PRELIMINARIES

The notation \oplus represents the *Minkowski sum* of two sets, $|\cdot|$ denotes the elementwise *absolute value* and the inequalities are interpreted elementwise.

A. Invariant Sets

The linear discrete time-invariant dynamics

$$x_{k+1} = A_o x_k + B_o \delta_k \quad (1)$$

are used to introduce the invariant set notions, where A_o and B_o are constant matrices and A_o is a Schur matrix, δ_k belongs to $\Delta = \{\delta : |\delta - \delta^\circ| \leq \bar{\delta}\}$ with δ° and $\bar{\delta}$ constant and all the elements have compatible dimensions.

Definition 2.1: (Invariant sets) A set $X \subset \mathbb{R}^n$ is called a *robust λ -contractive (robust positively invariant (RPI)) set* for (1) if and only if there exists a scalar $0 \leq \lambda < 1$ ($\lambda = 1$) such that $A_o X \oplus B_o \Delta \subseteq \lambda X$. \diamond

Definition 2.2: (The mRPI set) The *minimal robust positively invariant set (mRPI set)* with respect to (1) is defined as a RPI set contained in any closed RPI set. \diamond

Theorem 2.1: (Invariant sets) [4] Considering the dynamics (1) and letting $A_o = V \Lambda V^{-1}$ be the Jordan decomposition of A_o with Λ diagonal and V invertible, the set

$$\Phi(\theta) = \{x \in \mathbb{R}^n : |V^{-1}x| \leq (I - |\Lambda|)^{-1} |V^{-1}B_o| \bar{\delta} + \theta\} \oplus \xi^\circ \quad (2)$$

is RPI and attractive for the trajectories of (1), with θ any (arbitrarily small) vector with positive components, where ξ° is the center of the set that is expressed as $\xi^\circ = (I_n - A_o)^{-1} B_o \delta^\circ$ where I_n is the identity matrix.

- 1) For any θ , the set $\Phi(\theta)$ is (positively) invariant, that is, if $x_0 \in \Phi(\theta)$, then $x_k \in \Phi(\theta)$ for all $k \geq 0$.
- 2) Given $\theta \in \mathbb{R}^n, \theta > 0$, and $x_0 \in \mathbb{R}^n$, there exists $k^* \geq 0$ such that $x_k \in \Phi(\theta)$ for all $k \geq k^*$. \square

Remark 2.1: For $\theta > 0$, the set $\Phi(\theta)$ is contractive. But for $\theta = 0$, one can guarantee only the invariance and not the contractiveness of the set. \diamond

Proposition 2.1: (The mRPI set approximations) [4] Considering the dynamics (1), letting all eigenvalues of A_o be strictly inside the unit circle and denoting X_0 as a (RPI) initial set of (1), each of the set iterations

$$X_{j+1} = A_o X_j \oplus B_o \Delta, \quad j \in \mathbb{N},$$

where j denotes the j -th element in the set sequence and \mathbb{N} represents the set of natural numbers, is a (RPI) approximation of the mRPI set of (1). Moreover, as j tends to infinity, the set sequence converges to the mRPI set. \square

Remark 2.2: According to Theorem 2.1 and Proposition 2.1, one can compute a (RPI) approximation for the dynamics (1) with an arbitrarily expected approximate precision towards the mRPI set. \diamond

B. Zonotopes

According to [1] and [2], several definitions and properties of zonotopes are introduced.

Definition 2.3: (Zonotopes) Given a vector $p \in \mathbb{R}^n$ and a matrix $G \in \mathbb{R}^{n \times m} (n \leq m)$, a zonotope X with the order m is defined as $X = p \oplus G\mathbb{B}^m$. \diamond

Definition 2.4: (Interval hull) The interval hull $\square X$ of a zonotope $X = p \oplus G\mathbb{B}^r \subset \mathbb{R}^n$ is the smallest interval box that contains X and the expression of the interval hull is denoted as $\square X = \{x \mid |x_i - p_i| \leq \|G_i\|_1\}$, where G_i is the i -th row of G , and x_i and p_i are the i -th components of x and p , respectively. \diamond

Property 2.1: (Minkowski sum) Given two zonotopes $X_1 = p_1 \oplus G_1\mathbb{B}^{r_1} \subset \mathbb{R}^n$ and $X_2 = p_2 \oplus G_2\mathbb{B}^{r_2} \subset \mathbb{R}^n$, the Minkowski sum of them is also a zonotope denoted by $X_1 \oplus X_2 = \{p_1 + p_2\} \oplus [G_1 \ G_2]\mathbb{B}^{r_1+r_2}$. \blacklozenge

Property 2.2: (Mapping by a matrix) The image of a zonotope $X = p \oplus G\mathbb{B}^r \subset \mathbb{R}^n$ by a linear mapping matrix K can be computed as $KX = Kp \oplus KG\mathbb{B}^r$ by a standard matrix product. \blacklozenge

Property 2.3: (Zonotope reordering) Given a zonotope $X = p \oplus G\mathbb{B}^r \subset \mathbb{R}^n$ and an integer s (with $n < s < r$), denote by \hat{G} the matrix resulting from the recording of the columns of the matrix G in decreasing Euclidean norm. Then, $X \subseteq p \oplus [\hat{G}_T \ Q]\mathbb{B}^s$, where \hat{G}_T is obtained from the first $s - n$ columns of matrix \hat{G} and $Q \in \mathbb{R}^{n \times n}$ is a diagonal matrix that satisfies

$$Q_{ii} = \sum_{j=s-n+1}^r |\hat{G}_{ij}|, \quad i = 1, \dots, n. \quad \blacklozenge$$

III. PLANT MODELS AND INTERVAL OBSERVERS

In this section, the plant models with faults as well as interval observers are introduced.

A. Plant Models

The linear discrete time-invariant plant with faults is considered as

$$x_{k+1} = Ax_k + BF_{i_a} u_k + \omega_k, \quad (3a)$$

$$y_k = CG_{i_s} x_k + \eta_k, \quad (3b)$$

where $x_k \in \mathbb{R}^n$, $u_k \in \mathbb{R}^p$ and $y_k \in \mathbb{R}^q$ are states, inputs and outputs, respectively, $A \in \mathbb{R}^{n \times n}$, $B \in \mathbb{R}^{n \times p}$ and $C \in \mathbb{R}^{q \times n}$ are constant, $F_{i_a} \in \mathbb{R}^{p \times p}$ ($i_a \in \mathbb{I}_a = \{0, 1, 2, \dots, N\}$ where N denotes the number of considered actuator faults) is a diagonal matrix modeling the i_a -th actuator mode, F_0 is the identity matrix representing the healthy actuator mode, $G_{i_s} \in \mathbb{R}^{n \times n}$ ($i_s \in \mathbb{I}_s = \{0, 1, 2, \dots, M\}$ where M denotes the number of considered sensor faults) is a diagonal matrix modeling the i_s -th sensor mode, G_0 is the identity matrix representing the healthy sensor mode, $\omega_k \in W$ and $\eta_k \in V$ represents bounded uncertainties (disturbances, offsets, etc) in states and outputs, respectively, and the subscript k denotes the k -th discrete time¹.

All diagonal entries of F_{i_a} and G_{i_s} belong to $[0, 1]$ where 0 and 1 represent that the corresponding actuators/sensors are completely faulty or healthy, respectively, while a value in the range $(0, 1)$ denotes a partial degradation of the corresponding actuators/sensors. W and V are defined as

$$W = \{\omega_k \in \mathbb{R}^n : |\omega_k - \omega^c| \leq \bar{\omega}, \omega^c \in \mathbb{R}^n, \bar{\omega} \in \mathbb{R}^n\},$$

$$V = \{\eta_k \in \mathbb{R}^q : |\eta_k - \eta^c| \leq \bar{\eta}, \eta^c \in \mathbb{R}^q, \bar{\eta} \in \mathbb{R}^q\},$$

where $\omega^c, \eta^c, \bar{\omega}$ and $\bar{\eta}$ are constant vectors.

Due to the structure above, W and V can be rewritten as zonotopes

$$W = \omega^c \oplus H_{\bar{\omega}}\mathbb{B}^n, \quad (4a)$$

$$V = \eta^c \oplus H_{\bar{\eta}}\mathbb{B}^q, \quad (4b)$$

where \mathbb{B}^n and \mathbb{B}^q are unitary boxes (interval vectors) composed of n and q unitary intervals, respectively, $H_{\bar{\omega}} \in \mathbb{R}^{n \times n}$ and $H_{\bar{\eta}} \in \mathbb{R}^{q \times q}$ are diagonal matrices with the diagonal entry in each row having the same value with the corresponding entry in each row of $\bar{\omega}$ and $\bar{\eta}$, respectively.

Assumption 3.1: (Fault occurrence) The system keeps operating in a dynamic mode for a sufficiently long time such that it goes into steady state before a switching of dynamic mode induced by a fault occurrence. \blacksquare

Assumption 3.2: (Detectability and stabilizability) The pairs (A, BF_{i_a}) and (A, CG_{i_s}) are respectively stabilizable and detectable under all the considered modes. \blacksquare

B. Interval Observers

1) *The Notions of Interval Observers:* Assuming that the plant (3) is in the healthy mode, an observer based on the Luenberger structure

$$\hat{x}_{k+1} = A\hat{x}_k + Bu_k + L_0(y_k - \hat{y}_k) + \check{\omega}_k, \quad (5a)$$

$$\hat{y}_k = C\hat{x}_k + \check{\eta}_k, \quad (5b)$$

¹Generally, sensor faults are modeled as $y_k = \hat{G}_{i_s} Cx_k + \eta_k$, but for simplicity of mathematical derivations, in this paper they are modeled as $y_k = CG_{i_s} x_k + \eta_k$.

is designed, which includes uncertain variables $\check{\omega}_k \in W$ and $\check{\eta}_k \in V$, to model the effect of unknown disturbances ω_k and noises η_k in the real states x_k and outputs y_k of the plant, respectively, and where L_0 is an observer gain matrix that can ensure the observer convergence.

By introducing zonotope description of noises and disturbances as indicated in (4a) and (4b) into the observer mapping (5) and using zonotope arithmetic at each time instant [1], a healthy interval observer based on the Luenberger structure is given as

$$\hat{X}_{k+1}^0 = (A - L_0 C) \hat{X}_k^0 \oplus \{B u_k\} \oplus \{L_0 y_k\} \oplus (-L_0) V \oplus W, \quad (6a)$$

$$\hat{Y}_k^0 = C \hat{X}_k^0 \oplus V, \quad (6b)$$

where \hat{X}_k^0 and \hat{Y}_k^0 are respectively state and output zonotopes predicted by the interval observer at time instant k . Eventually, it is guaranteed that the predicted zonotopes for \hat{y}_k (or \hat{x}_k) confine both y_k (or x_k) and \hat{y}_k (or \hat{x}_k), respectively.

2) *Interval Observers for Actuator Faults:* In (3), letting G_{i_s} be the identity matrix, one can obtain the models of the plant under actuator faults. The interval observer corresponding to the model of the j_a -th system actuator mode is designed as

$$\hat{X}_{k+1}^{j_a} = (A - L_{j_a} C) \hat{X}_k^{j_a} \oplus \{B F_{j_a} u_k\} \oplus \{L_{j_a} y_k\} \oplus (-L_{j_a}) V \oplus W, \quad (7a)$$

$$\hat{Y}_k^{j_a} = C \hat{X}_k^{j_a} \oplus V, \quad (7b)$$

where $j_a \in \mathbb{I}_a$ represents the index of the interval observer ($j_a = 0$ denotes the healthy interval observer as seen in (6)), $\hat{X}_k^{j_a}$ and $\hat{Y}_k^{j_a}$ are state and output zonotopes predicted by the j_a -th interval observer at k , respectively, and L_{j_a} is an observer gain matrix which makes $A - L_{j_a} C$ be a Schur matrix.

According to (7) and zonotope operations, the center \hat{x}_{k+1}^{c,j_a} and segment matrix $\hat{H}_{k+1}^{j_a}$ of $\hat{X}_{k+1}^{j_a}$, and the center \hat{y}_k^{c,j_a} and segment matrix $\hat{H}_k^{j_a}$ of $\hat{Y}_k^{j_a}$ are computed as

$$\hat{x}_{k+1}^{c,j_a} = (A - L_{j_a} C) \hat{x}_k^{c,j_a} + B F_{j_a} u_k + L_{j_a} y_k - L_{j_a} \eta^c + w^c, \quad (8a)$$

$$\hat{H}_{k+1}^{j_a} = [(A - L_{j_a} C) \hat{H}_k^{j_a} \quad -L_{j_a} H_{\bar{\eta}} \quad H_{\bar{\omega}}], \quad (8b)$$

$$\hat{y}_k^{c,j_a} = C \hat{x}_k^{c,j_a} + \eta^c, \quad (8c)$$

$$\hat{H}_k^{j_a} = [C \hat{H}_k^{j_a} \quad H_{\bar{\eta}}]. \quad (8d)$$

3) *Interval Observers for Sensor Faults:* Similarly, in (3) letting F_{i_s} be the identity matrix, the models of the plant under sensor faults can be obtained. The interval observer corresponding to the j_s -th system sensor mode can be expressed as

$$\hat{X}_{k+1}^{j_s} = (A - L_{j_s} C G_{j_s}) \hat{X}_k^{j_s} \oplus \{B u_k\} \oplus \{L_{j_s} y_k\} \oplus (-L_{j_s}) V \oplus W, \quad (9a)$$

$$\hat{Y}_k^{j_s} = C G_{j_s} \hat{X}_k^{j_s} \oplus V, \quad (9b)$$

where $j_s \in \mathbb{I}_s$ represents the index of the interval observer ($j_s = 0$ denotes the healthy interval observer as seen in (6)) and the gain matrix L_{j_s} can make $A - L_{j_s} C G_{j_s}$ be a Schur

matrix. Similar with (8), the expressions of the center and segment matrix of $\hat{X}_{k+1}^{j_s}$ and $\hat{Y}_k^{j_s}$ can be derived.

Assumption 3.3: (Initial conditions) The initial state of the plant is denoted as x_0 and x_0 belongs to a known initial zonotope \hat{X}_0 for all the interval observers, i.e., $x_0 \in \hat{X}_0$. ■

Since the prediction of interval observers and the computation of interval vectors is based on zonotopes, the discussions in the remaining of the paper are mainly based on zonotopes.

Additionally, since the principle of the proposed technique for actuator and sensor FDI is similar, in this paper only FDI of actuator faults is discussed in detail. However, the extension of the method to the case of sensor faults is summarized afterwards.

IV. PROPOSED INTERVAL OBSERVER-BASED FDI

The interval observer-based FDI is introduced and the proposed FDI algorithm is presented.

A. FDI using Interval Observers

1) *FD using Interval Observers:* According to [3], the interval observer-based FD uses the healthy interval observer, which is based on propagating model uncertainties to the residuals and checking if

$$\mathbf{0} \in \square R_k^0, \quad (10)$$

where $R_k^0 = \{y_k\} \oplus (-\hat{Y}_k^0)$ denotes the residual zonotope predicted by the healthy interval observer at time instant k and $\mathbf{0}$ represents the zero vector. If (10) does not hold, it is assumed that a fault has occurred at k .

2) *FI using Interval Observers:* The proposed FI technique is based on a bank of interval observers and each observer is designed to match a given system mode. At each time instant, a set of residual zonotopes predicted by the bank of interval observers can be obtained. After the transition from one operating mode to another, the residual zonotope matching the current mode should include $\mathbf{0}$ and simultaneously all the other residual zonotopes not matching the current mode should always exclude $\mathbf{0}$.

B. FDI Algorithm using a Bank of Interval Observers

Since each interval observer matches one certain system mode, it means that each interval observer has different dynamical behaviors under different modes. Since a fault occurrence always induces the corresponding uncertainties on dynamical behaviors of interval observers during the transition, there exist possibilities that at some time instants several residual zonotopes predicted by several different interval observers simultaneously contain $\mathbf{0}$ during the transition.

In order to guarantee the correct and timely FI, a waiting time T is necessary after a fault is detected. This waiting time is used to delay FI process such that the incorrect FI possibilities are completely avoided. The procedure of this proposed FDI method is presented in Algorithm 1.

Definition 4.1: (Waiting time T) It is defined as, at least, the maximum of all the *settling time* of all the interval observers such that residual zonotopes predicted by interval

observes not matching the current system mode do exclude $\mathbf{0}$ by waiting T after the detection of a fault. \diamond

Algorithm 1 Proposed FDI algorithm

Require: x_0, \hat{X}_0 , mode index $i_a \in \mathbb{I}_a$;

Ensure: Current fault index f ;

- 1: Initialization: $\hat{X}_0^{j_a} = \hat{X}_0$ ($j_a \in \mathbb{I}_a$) and $fault \leftarrow FALSE$;
 - 2: At time instant k : $\mathbf{0} \in R_k^{i_a}$ and $\mathbf{0} \notin R_k^{j_a}$ ($j_a \in \mathbb{I}_a \setminus \{i_a\}$);
 - 3: **while** $fault \neq TRUE$ **do**
 - 4: $k \leftarrow k + 1$;
 - 5: Obtain $R_k^{i_a}$;
 - 6: **if** $\mathbf{0} \notin R_k^{i_a}$ **then**
 - 7: $fault \leftarrow TRUE$ (Fault detection);
 - 8: $k \leftarrow k + T$;
 - 9: **end if**
 - 10: **end while**
 - 11: Obtain: $R_k^{j_a}$, $j_a \in \mathbb{I}_a \setminus \{i_a\}$;
 - 12: **for** $j_a \in \mathbb{I}_a \setminus \{i_a\}$ **do**
 - 13: **if** $\mathbf{0} \in R_k^{j_a}$ **then**
 - 14: $f \leftarrow j_a$ (Fault isolation);
 - 15: **break**;
 - 16: **end if**
 - 17: **end for**
 - 18: **return** f ;
-

Remark 4.1: When a fault occurs, it always results in changes in the system outputs (or the inputs of interval observers) and induces a transition for the estimations of each interval observer. Theoretically, the transition is assessed by the observer *settling time*, i.e., the eigenvalues of the interval observer matrix. Thus, by adjusting observer gain matrices of all the interval observers, one can obtain a satisfactory waiting time to guarantee reliable FDI. However, this adjustment should depend on the particular applications. \diamond

V. GUARANTEED FDI CONDITIONS

This section establishes a set of FDI sufficient conditions based on a bank of interval observers.

A. Characterizing Residual Sets using Zonotopes

When the system is under the i_a -th actuator mode, the residual zonotopes predicted by the j_a -th interval observer is defined as

$$\begin{aligned} R_k^{i_a j_a} &= \{y_k\} \oplus (-\hat{Y}_k^{j_a}) \\ &= \{C x_k + \eta_k\} \oplus \{(-C \hat{X}_k^{j_a}) \oplus (-V)\} \\ &= C\{\{x_k\} \oplus (-\hat{X}_k^{j_a})\} \oplus \{\eta_k\} \oplus (-V). \end{aligned} \quad (11)$$

In order to describe the residual zonotopes defined in (11), one has to obtain $\tilde{X}_k^{i_a j_a}$ which is written as

$$\begin{aligned} \tilde{X}_k^{i_a j_a} &= \{x_k\} \oplus (-\hat{X}_k^{j_a}) \\ &= \{(x_k - \hat{x}_k^{c, j_a})\} \oplus \hat{H}_k^{j_a} \mathbb{B}^{s_k^{j_a}} \\ &= \tilde{x}_k^{c, i_a j_a} \oplus \tilde{H}_k^{i_a j_a} \mathbb{B}^{s_k^{j_a}}, \end{aligned} \quad (12)$$

where $\tilde{x}_k^{c, i_a j_a} = x_k - \hat{x}_k^{c, j_a}$, $\tilde{H}_k^{i_a j_a} = \hat{H}_k^{j_a}$ and $s_k^{j_a}$ represents the order of the zonotope $\hat{X}_k^{j_a}$.

According to (3) and (8), the center and segment matrix of $\tilde{X}_{k+1}^{i_a j_a}$ are computed as

$$\begin{aligned} \tilde{x}_{k+1}^{c, i_a j_a} &= (A - L_{j_a} C) \tilde{x}_k^{c, i_a j_a} + B(F_{i_a} - F_{j_a}) u_k \\ &\quad - L_{j_a} (\eta_k - \eta^c) + (\omega_k - \omega^c), \end{aligned} \quad (13a)$$

$$\tilde{H}_{k+1}^{i_a j_a} = \hat{H}_{k+1}^{j_a} = [(A - L_{j_a} C) \hat{H}_k^{j_a} \quad -L_{j_a} H_{\bar{\eta}} \quad H_{\bar{\omega}}]. \quad (13b)$$

In order to establish guaranteed FDI conditions, assume that all possible values of control inputs u_k belong to a set denoted as

$$U = \{u_k \in \mathbb{R}^p : |u_k - u^c| \leq \bar{u}, u^c \in \mathbb{R}^p, \bar{u} \in \mathbb{R}^p\},$$

where u^c and \bar{u} are constant. Moreover, U can be rewritten as a zonotope

$$U = u^c \oplus H_{\bar{u}} \mathbb{B}^p,$$

where $H_{\bar{u}} \in \mathbb{R}^{p \times p}$ is a diagonal matrix with the diagonal entry in each row having the same value with the corresponding entry in the same row of \bar{u} .

By substituting U , W and V to replace u_k , ω_k and η_k in (13a), respectively, one can compute a bounding zonotope denoted as $\check{X}_{k+1}^{i_a j_a}$ to bound $\tilde{X}_{k+1}^{i_a j_a}$ at time instant $k + 1$, and the center and segment matrix of $\check{X}_{k+1}^{i_a j_a}$ are derived as

$$\check{x}_{k+1}^{c, i_a j_a} = (A - L_{j_a} C) \check{x}_k^{c, i_a j_a} + B(F_{i_a} - F_{j_a}) u^c, \quad (14a)$$

$$\begin{aligned} \check{H}_{k+1}^{i_a j_a} &= [(A - L_{j_a} C) \hat{H}_k^{j_a} \quad B(F_{i_a} - F_{j_a}) H_u \quad -L_{j_a} H_{\bar{\eta}} \\ &\quad L_{j_a} H_{\bar{\eta}} \quad H_{\bar{\omega}} \quad -H_{\bar{\omega}}]. \end{aligned} \quad (14b)$$

Comparing (13) with (14), it is seen that as long as the dynamics of $\tilde{X}_{k+1}^{i_a j_a}$ and $\check{X}_{k+1}^{i_a j_a}$ are initialized under the condition $\tilde{X}_0^{i_a j_a} \subseteq \check{X}_0^{i_a j_a}$, after the initialization $\tilde{X}_{k+1}^{i_a j_a} \subseteq \check{X}_{k+1}^{i_a j_a}$ holds for all $k > 0$.

Thus, one can obtain the set-based dynamics of (14), which is derived as

$$\begin{aligned} \check{X}_{k+1}^{i_a j_a} &= (A - L_{j_a} C) \check{X}_k^{i_a j_a} \oplus B(F_{i_a} - F_{j_a}) U \oplus L_{j_a} (-V) \\ &\quad \oplus W \oplus L_{j_a} V \oplus (-W). \end{aligned} \quad (15)$$

In order to establish a set of guaranteed FDI conditions, this paper is interested in $\check{X}_{\infty}^{i_a j_a}$ at infinity. In fact, it is not possible to accurately compute $\check{X}_{\infty}^{i_a j_a}$. Then, one has to compute an approximation for $\check{X}_{\infty}^{i_a j_a}$ and as long as the precision of the approximation is satisfactory, it can be used to replace the use of $\check{X}_{\infty}^{i_a j_a}$.

By following Theorem 2.1 and Proposition 2.1, assigning an arbitrarily initial zonotope² for (15) and iterating (15), a satisfactory approximation of $\check{X}_{\infty}^{i_a j_a}$ denoted as $S_{i_a j_a}$ with the center $O_{i_a j_a}$ can be obtained.

²Note that according to Theorem 2.1 a RPI set of (15) can be obtained. Thus, if the initial zonotope is RPI, it is guaranteed that $S_{i_a j_a}$ is a RPI approximation of $\check{X}_{\infty}^{i_a j_a}$. If the initial is not RPI, a non-RPI approximation for $\check{X}_{\infty}^{i_a j_a}$ can be obtained. However, as long as the iterative time is sufficient, the non-RPI approximation can also be satisfactory.

B. Guaranteed FDI Conditions

For each considered system mode, an interval observer is designed to match the corresponding mode. According to (11) and (12), the residual zonotope at time instant k is rewritten as

$$R_k^{i_a j_a} = C \tilde{X}_k^{i_a j_a} \oplus \{\eta_k\} \oplus (-V). \quad (16)$$

By substituting V to replace η_k in (16), a residual-bounding zonotope $\check{R}_k^{i_a j_a}$ at k can be obtained as

$$\check{R}_k^{i_a j_a} = C \check{X}_k^{i_a j_a} \oplus V \oplus (-V). \quad (17)$$

As k tends to infinity, guaranteed FDI sufficient conditions based on $\check{R}_\infty^{i_a j_a}$ can be established.

Theorem 5.1: (Guaranteed FDI conditions) Considering the plant (3) and a bank of interval observers (7), as long as the residual-bounding zonotope $\check{R}_\infty^{i_a j_a}$ ($j_a \neq i_a$ and $i_a, j_a \in \mathbb{I}_a$) satisfies

$$|P_l(\mathbf{0} - \check{r}_{i_a j_a}^c)| > \max_{r \in \check{E}} |P_l(r - \check{r}_{i_a j_a}^c)|, \quad (18)$$

where $\check{r}_{i_a j_a}^c$ denotes the center of $\check{R}_\infty^{i_a j_a}$, \check{E} represents the set of all vertices of $\check{R}_\infty^{i_a j_a}$, $P_l(\cdot)$ represents the projection towards the axis $l \in \{1, 2, \dots, q\}$, once a fault occurs, the accurate FDI can be guaranteed after a waiting time.

Proof : The proof has two parts. The first part is to prove that $\check{R}_\infty^{i_a j_a}$ ($j_a \neq i_a$) does not contain $\mathbf{0}$, which is the asymptotic FDI condition. The second part concentrates on that the dynamical behavior of the residuals at infinity ($\check{R}_\infty^{i_a j_a}$) translates those after a waiting time, which guarantees the FDI reliability and accuracy.

The satisfaction of (18) implies that the limit set $\check{R}_\infty^{i_a j_a}$ does not contain 0. Thus, one only focuses on the proof of the second part as follows. Since residual zonotopes and their bounding zonotopes are determined by (13) and (14), without loss of effectiveness, the main elements used next will be these set-based dynamics.

The equation (15) shows that the time-variant term is $(A - L_{j_a} C) \check{X}_k^{i_a j_a}$, which means that the difference of values of $\check{X}_k^{i_a j_a}$ at different time instants is determined by the shape of $\check{X}_0^{i_a j_a}$, while the contractive factor is determined by the placement of the eigenvalues of $A - L_{j_a} C$ that corresponds to the j_a -th interval observer.

Thus, whenever a fault occurs, after a waiting time assessed by the eigenvalues of the interval observer, (15) enters into steady state. Then, the set value of $\check{X}_k^{i_a j_a}$ can be sufficiently³ close to that of $\check{X}_\infty^{i_a j_a}$, which means that $\check{X}_\infty^{i_a j_a}$ can approximately describe the dynamical behaviors of the system after the waiting time. \square

As long as Theorem 5.1 is satisfied, the FDI of any of considered faults can be guaranteed. However, since $\check{R}_\infty^{i_a j_a}$ can not be accurately computed but only approximated, Theorem 5.1 has only a theoretical value. For the sake of finding a set of practical FDI conditions, one has to turn

³ $\check{X}_k^{i_a j_a}$ is inside the set described as the Minkowski sum of $\{P_{i_a j_a}\} \oplus (1 + \epsilon)\{\check{X}_\infty^{i_a j_a} \oplus \{-P_{i_a j_a}\}\}$, where $P_{i_a j_a}$ denotes the center of $\check{X}_\infty^{i_a j_a}$ and ϵ is a scalar that satisfies $\epsilon > 0$.

to an approximation $S_{i_a j_a}$ of $\check{R}_\infty^{i_a j_a}$. Further, a satisfactory approximation of $\check{R}_\infty^{i_a j_a}$ is derived as

$$\hat{R}_\infty^{i_a j_a} = C S_{i_a j_a} \oplus V \oplus (-V), \quad (19)$$

where the center of $\hat{R}_\infty^{i_a j_a}$ is computed as

$$\hat{r}_{i_a j_a}^c = C O_{i_a j_a}. \quad (20)$$

Based on (19), (20) and Theorem 5.1, a set of usable FDI conditions can be established

$$|P_l(\mathbf{0} - \hat{r}_{i_a j_a}^c)| > \max_{r \in \hat{E}} |P_l(r - \hat{r}_{i_a j_a}^c)|, \quad (21)$$

where \hat{E} represents the set of all vertices of $\hat{R}_\infty^{i_a j_a}$ ($j_a \neq i_a$).

Note that the guaranteed FDI conditions are a set of sufficient conditions, not necessary conditions due to the series of approximations contained in the design method. Thus, their satisfaction can guarantee FDI, but the dissatisfaction does not mean that the faults are non-detectable or non-isolable with extra effort.

VI. THE EXTENSION FOR SENSOR FAULTS

When the plant (3) is under a sensor fault, similarly, residual zonotopes predicted by the j_s -th interval observers under the i_s -th system mode can be derived as

$$\begin{aligned} R_k^{i_s j_s} &= \{y_k\} \oplus (-\hat{Y}_k^{j_s}) \\ &= \{C G_{i_s} x_k + \eta_k\} \oplus \{(-C G_{j_s} \hat{X}_k^{j_s}) \oplus (-V)\} \\ &= \{C G_{i_s} x_k\} \oplus (-C G_{j_s} \hat{X}_k^{j_s}) \oplus \{\eta_k\} \oplus (-V). \end{aligned} \quad (22)$$

In order to establish a set of sensor FDI conditions like (18) in the case of actuator faults, in the i_s -th mode one has to compute the corresponding bounding zonotope $\check{R}_k^{i_s j_s}$ to bound $R_k^{i_s j_s}$ at each time instant. According to (22), one further has

$$\begin{aligned} \check{R}_k^{i_s j_s} &\subseteq C G_{i_s} \{\{x_k\} \oplus (-\hat{X}_k^{j_s})\} \oplus C(G_{i_s} - G_{j_s}) \hat{X}_k^{j_s} \\ &\quad \oplus \{\eta_k\} \oplus (-V). \end{aligned} \quad (23)$$

As discussed in the previous sections, the bounding zonotopes of $\{x_k\} \oplus (-\hat{X}_k^{j_s})$ and $\hat{X}_k^{j_s}$, respectively denoted as $\check{X}_k^{i_s j_s}$ and $\check{X}_k^{j_s}$, can be computed in the same way. Thus, $\check{R}_k^{i_s j_s}$ to bound $R_k^{i_s j_s}$ can be derived as

$$\check{R}_k^{i_s j_s} = C G_{i_s} \check{X}_k^{i_s j_s} \oplus C(G_{i_s} - G_{j_s}) \check{X}_k^{j_s} \oplus V \oplus (-V).$$

Similarly, by obtaining satisfactory approximations of $\check{X}_\infty^{i_s j_s}$ and $\check{X}_\infty^{j_s}$, the corresponding approximation $\hat{R}_\infty^{i_s j_s}$ for $\check{R}_\infty^{i_s j_s}$ can be obtained. Thus, based on the same principle with the case of actuator faults, a set of guaranteed FDI conditions can be established for sensor FDI.

However, from the derivation indicated in (23), it is shown that the proposed method for sensor FDI is conservative. Thus, in this paper the discussions are restricted to this remark. Note that, if a less conservative method can be found, the conservativeness of guaranteed FDI conditions for sensor faults will be further reduced, which will be an important point of our further research.

VII. NUMERICAL EXAMPLE

The dynamics of the second blade subsystem of a wind turbine benchmark indicated in [7] are used for the illustrative example. Considering the length of this paper, please refer to Eqs.(4), (5) and (6) in [7] for the details of the subsystem dynamics structure.

1) *The Case of Actuator Faults:* We assume that the dynamics have two actuator-fault modes, i.e, the dynamics Eq.(4) in [7] are rewritten as

$$x_{\beta_2}^+ = A_{\beta_2}x_{\beta_2} + B_{\beta_2}F_{i_a}(\beta_r + \beta_{2f}), \quad (24)$$

$$\beta_2 = C_{\beta_2}x_{\beta_2}, \quad (25)$$

where the notation $+$, consistent with [7] for simplicity, denotes the successor time instant, F_{i_a} models the i_a -th actuator mode ($i_a \in \{0, 1, 2\}$) and F_0 , the identity matrix, represents the healthy actuator mode.

We assume that the two sensors of the subsystem are healthy (i.e., $K = 1$ in Eq.(5) of [7]) and that the feedback β_{2f} is obtainable. Three interval observers are designed as indicated in (7) corresponding to the three modes. After system discretization with the sampling time $0.01s$, the parameters of the discrete-time dynamics are given as

- model parameters:

$$A_{\beta_2} = \begin{bmatrix} 0.8667 & -1.2343 \\ 0.01 & 1 \end{bmatrix}, \quad B_{\beta_2} = \begin{bmatrix} 0.01 \\ 0 \end{bmatrix},$$

$$C_{\beta_2} = \begin{bmatrix} 0 & 123.4321 \end{bmatrix},$$

- measurement noises:

$$\bar{\eta}_{\beta_2,m1} = 0.03, \quad \eta_{\beta_2,m1}^c = 0.3,$$

$$\bar{\eta}_{\beta_2,m2} = 0.03, \quad \eta_{\beta_2,m2}^c = 0.3,$$

- Three observer gains:

$$L_0 = L_1 = L_2 = \begin{bmatrix} -0.001 \\ 0.003 \end{bmatrix},$$

- fault magnitude:

$$F_1 = [0.1], \quad F_2 = [0.5],$$

- sinusoidal control input:

$$\beta_r^c = 3, \quad H_{\beta_r} = 0.3,$$

- initial conditions:

$$x_{\beta_{20}} = \begin{bmatrix} 0 \\ 0 \end{bmatrix}, \quad \hat{x}_0^{c,0} = \hat{x}_0^{c,1} = \hat{x}_0^{c,2} = \begin{bmatrix} 0.1 \\ 0.1 \end{bmatrix},$$

$$\hat{H}_0^0 = \hat{H}_0^1 = \hat{H}_0^2 = \begin{bmatrix} 0.5 & 0 & 0 & 0 \\ 0 & 0 & 0.5 & 0 \end{bmatrix}.$$

By iterating (15) thirty steps to obtain a satisfactory approximation of $\hat{X}_{\infty}^{i_a j_a}$, and according to (17), the corresponding approximation of residual-bounding zonotope $\hat{R}_{\infty}^{i_a j_a}$ is computed. Eventually, all approximations of all relevant residual-bounding zonotopes are presented as

- for the interval observer 0:

$$\hat{R}_{\infty}^{10} = [-0.8325, -0.2937],$$

$$\hat{R}_{\infty}^{20} = [-0.5570, -0.0778],$$




Fig. 1. The FDI of actuator faults

- for the interval observer 1:

$$\hat{R}_{\infty}^{01} = [0.2889, 0.8015],$$

$$\hat{R}_{\infty}^{21} = [0.0187, 0.4567],$$

- for the interval observer 2:

$$\hat{R}_{\infty}^{02} = [0.0730, 0.5255],$$

$$\hat{R}_{\infty}^{12} = [-0.4732, -0.0352],$$

which shows that all the three considered actuator modes can satisfy the FDI conditions as indicated in (21). The simulation scenarios are considered as: from 0 to 50 the system is healthy, from 51 to 80 the second fault occurs, from 81 to 110 the system recovers to health and from 111 to 140 the first fault occurs.

The simulation results presented in Figure 1 show the effectiveness of this approach, where a transition appears when a fault occurs, which implies that the waiting time is necessary for the accurate FI.




Fig. 2. The FDI of sensor faults

2) *The Case of Sensor Faults:* The original dynamics of the second blade subsystem characterized by Eqs.(4), (5) and (6) in [7] is used. The sensor faults are located in the second sensor described by Eq.(5) of [7]. In this simulation, the magnitudes of two sensor fault modes 1 and 2 are set as

$$K_1 = 0.5, \quad K_2 = 0.05.$$

Noises and control inputs (all the other parameters respect those in the case of actuator faults) are given as

- measurement noises:

$$\begin{aligned}\bar{\eta}_{\beta_2,m1} &= 0.005, \quad \eta_{\beta_2,m1}^c = 1.5, \\ \bar{\eta}_{\beta_2,m2} &= 0.005, \quad \eta_{\beta_2,m2}^c = 1.5.\end{aligned}$$

- sinusoidal control input:

$$\beta_r^c = 15, \quad H_{\beta_r} = 0.03.$$

Similarly, by iterating the corresponding bounding zonotopes like (15) 50 steps, one computes the approximations of all relevant residual-bounding zonotopes

- for the interval observer 0:

$$\begin{aligned}\hat{R}_{\infty}^{10} &= [-10.400, -10.249], \\ \hat{R}_{\infty}^{20} &= [-229.38, -227.53],\end{aligned}$$

- for the interval observer 1:

$$\begin{aligned}\hat{R}_{\infty}^{01} &= [1.2694, 1.5076], \\ \hat{R}_{\infty}^{21} &= [-0.9769, -0.9292],\end{aligned}$$

- for the interval observer 2:

$$\begin{aligned}\hat{R}_{\infty}^{02} &= [0.8013, 4.4751], \\ \hat{R}_{\infty}^{12} &= [-4.2844, -3.2450],\end{aligned}$$

which satisfy the corresponding guaranteed FDI conditions like (21).


Similarly, one sets simulation scenarios: from 0 to 40 the system is healthy, from 41 to 80 the first fault occurs, from 81 to 120 the system recovers to health and from 121 to 170 the second fault occurs. The simulation results presented in Figure 2 and Figure 3 illustrate the effectiveness of the method for sensor FDI.

VIII. CONCLUSIONS


This paper proposes an interval observer-based guaranteed FDI approach by using a bank of interval observers. For guaranteed FDI, a set of FDI conditions are established by analyzing the limit sets connected with invariant set notions. The advantage of the approach is that it can precheck whether the faults are detectable and isolable without the need of guaranteeing that residual zonotopes predicted by all the interval observers are separatable from each other. The following research is to explore ways of further reducing the conservativeness of FDI conditions for sensor faults.

ACKNOWLEDGEMENTS


The work of F. Xu, V. Puig and C. Ocampo-Martinez has been supported by the Spanish research project WATMAN (CICYT DPI2009-13744) of the Science and Technology Ministry and by the DGR of Generalitat de Catalunya (SAC group Ref. 2009/SGR/1491), and by European Commission through contract i-Sense (FP7-ICT-2009-6-270428). F. Xu is also supported by the China Scholarship Council (File No.2011629170). Acknowledgements to Juan Manuel Grosso for significant discussions.



(a) Observer 0



(b) Observer 1



(c) Observer 2

Fig. 3. The scaling-up of the Fig.2

REFERENCES

- [1] T. Alamo, J.M. Bravo, and E.F. Camacho. Guaranteed state estimation by zonotopes. In *Decision and Control, 2003. Proceedings. 42nd IEEE Conference on*, pages 5831 – 5836, Maui, Hawaii, USA, December 2003.
- [2] P. Guerra, V. Puig, and M. Witczak. Robust fault detection with unknown-input interval observers using zonotopes. In *Proceedings of the 17th World Congress, The International Federation of Automatic Control*, COEX, Seoul, South Korea, July 2008.
- [3] J. Meseguer, V. Puig, and T. Escobet. Robust fault detection linear interval observers avoiding the wrapping effect. In *Proceedings of the 17th World Congress, The International Federation of Automatic Control*, COEX, Seoul, South Korea, July 2008.
- [4] S. Olaru, J.A. De Doná, M.M. Seron, and F. Stoican. Positive invariant sets for fault tolerant multisensor control schemes. *International Journal of Control*, 83(12):2622–2640, 2010.
- [5] V. Puig, J. Quevedo, T. Escobet, and A. Stancu. Passive robust fault detection using linear interval observers. In *IFAC Safe Process*, Washington, USA, 2003.
- [6] P. Rosa. *Multiple-Model Adaptive Control of Uncertain LPV Systems*. PhD thesis, Electrical and Computer Engineering, Instituto Superior Técnico, Portugal, 2011.
- [7] F. Stoican, C.F. Raduinea, and S. Olaru. Adaptation of set theoretic methods to the fault detection of a wind turbine benchmark. In *Proceedings of the 18th IFAC World Congress*, pages 8322–8327, Milano, Italy, 28 August–2 September 2011.