

# Robust LPV Model-Based Sensor Fault Diagnosis Using Relative Fault Sensitivity Signature and Residual Directions Approaches in a PEM Fuel Cell

S. de Lira and V. Puig and J. Quevedo

Research group of Automatic Control Departament of  
Technical University of Catalonia (UPC)  
Pau Gargallo, 5, 08028 Barcelona  
Email: salvador.de.lira@upc.edu

A. Husar

Institut de Robtica i Informtica Industrial (CSIC-IRI)  
Barcelona Technology Park  
Carrer Llorens i Artigas 4-6, Barcelona  
Email: ahusar@iri.upc.edu

**Abstract**—In this paper, a model-based fault diagnosis methodology for PEM fuel cell systems is presented. The methodology is based on computing residuals using an LPV observer. Sensor fault detection faces the problem of robustness using adaptive thresholds generated with interval observer. Fault isolation is performed using the Euclidean distance between the observed relative residuals and theoretical relative sensitivities. To illustrate the results, a commercial fuel cell Ballard Nexa<sup>®</sup> is used in simulation where a set of typical fault scenarios have been considered. Finally, the diagnosis results corresponding to those fault scenarios are presented. It is remarkable that with this methodology it is possible to diagnose all the considered faults in contrast with other well known methodologies which use the classic binary signature matrix approach.

**Index Terms**—Fault Detection; Fault Isolation, Fault Isolation, PEM Fuel Cell

## I. INTRODUCTION

The energy generation systems based on fuel cells are complex since they involve thermal, fluidic and electrochemical phenomena. Moreover, they need a set of auxiliary elements (valves, compressor, sensors, regulators, etc.) to make the fuel cell working at the pre-established optimal operating point. For these reasons, they are vulnerable to faults that can cause a emergency shut down or a permanent damage of the fuel cell. To guarantee a safe operation of the fuel cell systems, it is necessary to use systematic techniques, like the recent methods of Fault Tolerant Control (FTC) in [1], which allow increasing the fault tolerance of this technology. The first task to achieve active tolerant control is based on the inclusion of a fault diagnosis system operating in real-time. The diagnosis system should not only allow the fault detection and isolation but also the fault magnitude estimation.

In this paper, a model based fault diagnosis approach is proposed as a way to diagnose faults in fuel cell systems. The model-based fault diagnosis is based on comparing on-line the real behavior of the monitored system obtained by means of sensors with a predicted behavior obtained using a Linear Parameter Varying (LPV) dynamic model with an Luenberger observer scheme [2]. In case of a significant discrepancy (*residual*) is detected between the observer outputs and the

measurements obtained by the sensors, the existence of a fault is assumed. Fault isolation is based on generating a set of residuals with the available sensors thanks to they present different directional sensitivity to the set of possible faults.

The contributions of this paper are: first, the use of a LPV observer for fault detection and the second and the most important is the fact that dealing with fault relative sensitivity approach methodology for fault isolation is presented for the kind of faults that otherwise would not be separable using a classic fault isolation approach.

## II. FOUNDATIONS OF THE FAULT DIAGNOSIS METHODOLOGY

The proposed methodology of fault diagnosis for fuel cell systems which is used in this paper is mainly based on classic FDI theory of model-based diagnosis described in [3], [4] and [5].

The task of fault diagnosis consists of determining the type of fault with as much details as possible (fault location, time and size). Thus, two subtasks can be considered: *fault detection* and *fault isolation*. The principle of model-based fault detection is based on checking the consistency of measured ( $\mathbf{y}_k$ ) and predicted behaviors ( $\hat{\mathbf{y}}_k$ ) by computing residuals  $\mathbf{r}_k$ . Those residuals are obtained from the discrepancy of measured input ( $\mathbf{u}_k$ ) and outputs ( $\mathbf{y}_k$ ) using the set of sensors installed and the analytical relations obtained by system modeling:

$$\mathbf{r}_k = \psi(\mathbf{y}_k, \mathbf{u}_k) \quad (1)$$

where  $\psi$  is the residual generator function that depends on the type of detection strategy used (parity equation [3] or observer [6]). At each time instance,  $k$ , the residual is compared with a threshold value that should be determined taking into noise and modelling uncertainty.

Considering the whole set of residuals available, a set of *fault indicators*,  $\phi_k = [\phi_{1k}, \phi_{2k} \dots, \phi_{n_\phi}]$  are obtained as follows:

$$\phi_{ik} = \begin{cases} 0 & \text{if } |\mathbf{r}_i| \leq \tau_i \\ 1 & \text{if } |\mathbf{r}_i| > \tau_i \end{cases} \quad (2)$$

where  $\tau_i$  is the threshold associated to the residual  $\mathbf{r}_i(k)$ . Fault isolation consists of identifying the fault that affects the system. It is carried out by using the fault indicators,  $\phi$  (generated by the detection module) and its relation with all the considered faults,  $\mathbf{f}_k = \{f_{1k}, f_{1k}, \dots, f_{nk}\}$ . The method most often applied is based on the relation defined on the Cartesian product of the set of faults  $FSM \subset \phi \times \mathbf{f}$ , where  $FSM$ , known, the *theoretical fault signature matrix* [3]. An element  $FSM_{ij}$  of this matrix will be one, if a fault  $f_{jk}$  is affected by the residual  $\mathbf{r}_{ik}$ . In this case, the value of the fault indicator  $\phi_i(k)$  must be equal to one when the fault appears in the monitored system. Otherwise, the element  $FSM_{ij}$  will be zero. Fault signature matrix can be obtained from the structural analysis of analytical relations coming from the model and the set of available sensors [1].

Sensitivity analysis is the key point in the evaluation of fault symptoms in order to obtain a final diagnosis, identification of significant and problematic components plays an important role. That sensitivity analysis require understanding the system structure and component relationships. According to [3], the sensitivity of the residual to a fault is given by

$$S_f = \frac{\partial r}{\partial f} \quad (3)$$

which is a transfer function that describes the effect on the residual ( $r$ ) of a given fault ( $f$ ). Sensitivity provides quantitative information about the effect of the fault on the residual and qualitative information in their sense of variation (sign). The use of this information at the stage of diagnosis allows to separate faults that although show the same theoretical binary fault signature, they present different sensitivity values.

### III. FAULT DETECTION

Many model-based fault detection techniques, are mostly based on linear models. However, fuel cells are inherently non-linear [7]. An attractive alternative to represent non-linear systems is to use techniques based on LPV models. The LPV approach is particularly appealing whenever non-linear plants can be modeled as a linear time-varying systems with on-line measurable state depending parameters as is the case of PEM fuel cells.

#### A. Linear Parameter Varying Model

A LPV system in discrete-time state space form with input and output sensor faults can be expressed as

$$\begin{aligned} \mathbf{x}_{k+1} &= \mathbf{A}(\vartheta_k)\mathbf{x}_k + \mathbf{B}(\vartheta_k)\mathbf{u}_k + \mathbf{F}_a(\vartheta_k)\mathbf{f}_{ak} + \mathbf{w}_k \\ \mathbf{y}_k &= \mathbf{C}(\vartheta_k)\mathbf{x}_k + \mathbf{D}(\vartheta_k)\mathbf{u}_k + \mathbf{F}_y(\vartheta_k)\mathbf{f}_{yk} + \mathbf{v}_k \end{aligned} \quad (4)$$

where  $\mathbf{x}_k \in \mathbb{R}^{n_x}$ ,  $\mathbf{u}_k \in \mathbb{R}^{n_u}$  and  $\mathbf{y}_k \in \mathbb{R}^{n_y}$  are, respectively, the state, input, and output vectors,  $\mathbf{A}$ ,  $\mathbf{B}$ ,  $\mathbf{C}$ ,  $\mathbf{D}$  are the parameter model at  $\vartheta_k$ ,  $f_y(k) \in \mathbb{R}^{n_y}$  and  $f_a(k) \in \mathbb{R}^{n_u}$  represent faults in the system output sensors and actuators respectively being  $F_y(\vartheta) \in \mathbb{R}^{n_y \times n_y}$  and  $F_a(\vartheta) \in \mathbb{R}^{n_y \times n_u}$  their associated matrices, in faultless mode the  $\mathbf{f}_a$  and  $\mathbf{f}_y$  are zeros. The process and measurement noises are  $\mathbf{w}_k \in \mathbb{R}^{n_x}$

and  $\mathbf{v}_k \in \mathbb{R}^{n_y}$ .  $\vartheta_k \in \mathbb{R}^{n_\theta}$  is the system vector of time-varying parameters that change with the operating point scheduled by some measured system variables  $p_k$  ( $p_k := p(k)$ ) that can be estimated using some known function:

$$\vartheta_k = f(p_k) \quad (5)$$

The type of LPV systems considered in this paper assumes an affine dependence within the parameter vector  $\Theta$  space:

$$\Theta = \{ \vartheta_k \in \mathbb{R}^{n_\theta} \mid \underline{\vartheta}_k \leq \vartheta_k \leq \overline{\vartheta}_k \}$$

There exists different ways to obtain a LPV model for a non-linear system. Some methods use directly the non-linear equations of the system to derive the LPV model (using for example a state transformation or the Jacobian linearization) [8]. Another kind of methods uses multi-model identification that consists basically in two different steps. First part, a set of LTI model is identified at different equilibrium points by classical methods (*on-line* or *off-line*). As second part of this methodology a multi-model is obtained by using an interpolation law that commutes the local LTI model according to the operating point[9].

#### B. Linear Parameter Varying Observer

A LPV observer with *Luenberger* structure for the state estimation of the system described in Eq. (4) is given by

$$\begin{aligned} \hat{\mathbf{x}}_{k+1} &= \mathbf{A}(\vartheta_k)\hat{\mathbf{x}}_k + \mathbf{B}(\vartheta_k)\mathbf{u}_k + \\ &\quad \mathbf{L}(\vartheta_k)(\mathbf{y}_k - \hat{\mathbf{y}}_k) + \mathbf{F}_a(\vartheta_k)\mathbf{f}_{ak} \\ \hat{\mathbf{y}}_k &= \mathbf{C}(\vartheta_k)\hat{\mathbf{x}}_k + \mathbf{D}(\vartheta_k)\mathbf{u}_k + \mathbf{F}_y(\vartheta_k)\mathbf{f}_{yk} \end{aligned} \quad (6)$$

$$\begin{aligned} \hat{\mathbf{x}}_{k+1} &= \mathbf{A}(\vartheta_k)\hat{\mathbf{x}}_k + \mathbf{B}(\vartheta_k)\mathbf{u}_k + \\ &\quad \mathbf{L}(\vartheta_k)(\mathbf{y}_k - \hat{\mathbf{y}}_k) + \mathbf{F}_a(\vartheta_k)\mathbf{f}_{ak} \\ \hat{\mathbf{y}}_k &= \mathbf{C}(\vartheta_k)\hat{\mathbf{x}}_k + \mathbf{D}(\vartheta_k)\mathbf{u}_k + \mathbf{F}_y(\vartheta_k)\mathbf{f}_{yk} \end{aligned} \quad (7)$$

where  $\mathbf{L}$  is the observer gain to be designed to guarantee stability for  $\vartheta_k \in \Theta$ . This gain is computed at operating point  $\vartheta_k$  using LMI formulation for Pole-Placement within a wide class of pole clustering regions that is founded in an extended Lyapunov Theorem (see [10]). The motivation for seeking pole clustering in specific regions inside the unitary circle is to obtain a fast observer dynamics for all considered operating points.

#### C. LPV interval observer

**Definition 1.** Consider the state estimator given by Eq. (4) in faultless mode, an initial compact set  $\mathbb{X}_0$  and a sequence of measured inputs  $(\mathbf{u}_j)_0^{k-1}$  and outputs  $(\mathbf{y}_j)_0^k$ . The *exact uncertain estimated state set* at time  $k$  is expressed by

$$\begin{aligned} \mathbb{X}_k = \{ \hat{\mathbf{x}}_k : (\hat{\mathbf{x}}_j = \mathbf{A}(\vartheta_{j-1})\hat{\mathbf{x}}_{j-1} + \mathbf{B}(\vartheta_{j-1})\mathbf{u}_{j-1} \\ + \mathbf{w}_{j-1} + \mathbf{L}(\mathbf{y}_{j-1} - \hat{\mathbf{y}}_{j-1}))_{j=1}^k, \\ (\hat{\mathbf{y}}_{j-1} = \mathbf{C}\hat{\mathbf{x}}_{j-1} + \mathbf{v}_{j-1})_{j=1}^k \mid \mathbf{x}_0, \hat{\mathbf{x}}_0 \in \mathbb{X}_0, \\ (\vartheta_{j-1} \in \Theta, \mathbf{w}_{j-1} \in \mathbb{W}_{j-1}, \mathbf{v}_{j-1} \in \mathbb{V}_{j-1})_{j=1}^k \} \end{aligned} \quad (8)$$

The uncertain state set described in *Definition 1* at time  $k$  can be computed as approximation of uncertain state set at time  $k-1$ . A exhaustive computing process could be presented if the exact set of estimated states is required. In order to reduce complexity a bounded set could be used such as a box (*interval hull*) or other geometric regions easy to compute. Before introducing such algorithm, an additional definition should be introduced.

**Definition 2.** Consider the state estimator given by Eq. (4), the set of uncertain states at time  $k-1$ ,  $\mathbb{X}_{k-1}$  and the input/output values ( $\mathbf{u}_{k-1}, \mathbf{y}_{k-1}, \mathbf{y}_k$ ). Then, the **approximated set of estimated states** at time  $k$  based on the measurements up to time  $k-1$  is defined as

$$\begin{aligned} \mathbb{X}_k^e = \{ & \hat{\mathbf{x}}_k : \mathbf{A}(\vartheta_{k-1})\hat{\mathbf{x}}_{k-1} + \mathbf{B}(\vartheta_{k-1})\mathbf{u}_{k-1} + \mathbf{w}_{k-1} \\ & + \mathbf{L}(\mathbf{y}_{k-1} - \hat{\mathbf{y}}_{k-1}), \quad \hat{\mathbf{y}}_{k-1} = \mathbf{C}\hat{\mathbf{x}}_{k-1} + \mathbf{v}_{k-1} \\ & | \quad \hat{\mathbf{x}}_{k-1} \in \mathbb{X}_{k-1}, \vartheta_{k-1} \in \Theta, \bar{\mathbf{w}}_{k-1} \in \mathbb{W}_{k-1}, \mathbf{v}_{k-1} \in \mathbb{V}_{k-1} \} \end{aligned} \quad (9)$$

Analogously, considering a measurement equation in (4) the approximated set of estimated outputs  $\mathbb{Y}_k^e$  can be determined.

Using previous definition, the set of estimated states (or outputs) introduced in *Definition 1* will be approximated iteratively using zonotopes. From these zonotopes, an interval for each state variable can also be obtained by computing the interval hull of the zonotope. The sequence of interval hulls  $\square \mathbb{X}_k^e$  with  $k \in [0, N]$  will be called the **interval observer estimation** of the system given by Eq. (4). Analogously, the sequence of interval hulls  $\square \mathbb{Y}_k^e$  can be obtained. Following previous idea, *Algorithm 1* is proposed to determine an approximation of **set of uncertain estimated states**.

---

**Algorithm 1** Fault Detection using Interval observer

---

```

1: fault  $\leftarrow$  FALSE
2:  $k \leftarrow 0$ 
3:  $\mathbb{X}_k^e \leftarrow \mathbb{X}_0$ 
4: while fault = FALSE do
5:   Obtain input-output data  $\{\mathbf{u}_k, \mathbf{y}_k\}$ 
6:   Compute the approximated set of estimated states,  $\mathbb{X}_k^e$ 
7:   Compute the approximated set of estimated outputs,  $\mathbb{Y}_k^e$ 
8:   Compute the interval hull of the approximated set of
       estimated states,  $\square \mathbb{X}_k^e = [\underline{\mathbf{x}}_k, \bar{\mathbf{x}}_k]$ 
9:   Compute the interval hull of the approximated set of
       estimated outputs,  $\square \mathbb{Y}_k^e = [\underline{\mathbf{y}}_k, \bar{\mathbf{y}}_k]$ 
10:  if  $[\mathbf{y}_k] \cap \mathbb{Y}_k^e = \emptyset$  then
11:    fault  $\leftarrow$  TRUE
12:  end if
13:   $k \leftarrow k + 1$ 
14: end while

```

---

#### D. Residual Generation

The application of interval observers to fault detection involves in testing whether the measured output is consistent with the one given by the observer using a faultless model

and parameter uncertainty. If an inconsistency is detected, the existence of a fault is proved. The consistency match is based on generating a residual by comparing the measurements of physical variables  $\mathbf{y}_k$  of the process with their estimation  $\hat{\mathbf{y}}_k$  provided by the observer:

$$\mathbf{r}_k = \mathbf{y}_k - \hat{\mathbf{y}}_k \quad (10)$$

where  $\mathbf{r}_k \in \mathbb{R}^{n_y}$  is the residual set. Then, the fault detection test consists in checking the satisfaction of:

$$|\mathbf{r}_{ik}| \leq \tau_{ik} \quad (11)$$

where  $\tau_{ik}$  is the threshold associated to the residual  $\mathbf{r}_{ik}$ . In case that this condition is not satisfied a fault can be indicated.

## IV. FAULT ISOLATION

### A. Fault Sensitivity Analysis

The isolation approach presented in Section II uses a set of binary detection (*Boolean*) tests to compose the observed fault signature. However, the use of binary codification of the residual produces a lack of information that can lead to wrong diagnosis when applied to dynamic systems. This derives in some faults that are not isolable because they present the same theoretical binary fault signature [11]. To avoid this problem is possible to use additional information associated with the relationship between the residuals and faults, such as sign, sensitivity, and order or activation time, to improve the isolation results [11].

### B. Proposed methodology

In this work, a new method for fault diagnosis system design is proposed that exploits the information provided by the sensitivity in the case where the fault magnitude is unknown.

1) *Sensitivity of the residual to an output sensor fault:* Considering computational form of the residual generator using Eq. (11) and input-output format of plant model with  $q$ -shift expressed in terms of the effects caused by faults

$$\begin{aligned} \mathbf{r}(k) = & \mathbf{r}_o(k) + (\mathbf{I} - \mathbf{H}(q^{-1}, \vartheta))(\mathbf{G}_{f_a}(q^{-1}, \tilde{\vartheta})\mathbf{f}_a(k) \\ & + \mathbf{G}_{f_y}(q^{-1}, \tilde{\vartheta})\mathbf{f}_y(k)) - \mathbf{G}_{f_u}(q^{-1}, \tilde{\vartheta})\mathbf{f}_u(k) \end{aligned} \quad (12)$$

where

$$\mathbf{r}_o(k) = -\mathbf{G}(q^{-1}, \vartheta)\mathbf{u}_o(k) + (\mathbf{I} - \mathbf{H}(q^{-1}, \vartheta))\mathbf{y}_o(k) \quad (13)$$

Considering the residual internal form given by Eq. (12) and considering the fault residual sensitivity definition given by Eq. (3), it is possible to compute the sensitivity for the case of an output sensor fault,  $f_y$ , which is given in  $q$ -transfer form by a transfer function matrix  $\mathbf{S}_{f_y}$  with size of  $n_y \times n_y$ , expressed as:

$$\begin{aligned} \mathbf{S}_{f_y}(q^{-1}, \vartheta) = & \left( \mathbf{I} + \mathbf{C}^y(\vartheta)(q\mathbf{I} - \mathbf{A}^y(\vartheta))^{-1} \right) \mathbf{B}^y(\vartheta) \\ & \mathbf{D}^y(\vartheta) \\ = & (\mathbf{I} + \mathbf{H}_r^y(q^{-1}, \vartheta))^{-1} \mathbf{F}_y(\vartheta) \end{aligned} \quad (14)$$

where  $\mathbf{A}^y(\vartheta) = \mathbf{A}(\vartheta) - \mathbf{L}(\vartheta)\mathbf{C}(\vartheta)$ ,  $\mathbf{B}^y = \mathbf{F}_y(\vartheta)\mathbf{f}_y$ ,  $\mathbf{C}^y(\vartheta) = \mathbf{C}(\vartheta)$ ,  $\mathbf{D}^y(\vartheta) = \mathbf{D}(\vartheta)$  and  $\mathbf{H}_r^y(q^{-1}, \vartheta) = \mathbf{C}^y(q\mathbf{I} - \mathbf{A}^y(\vartheta))\mathbf{B}^y(\vartheta) + \mathbf{D}^y(\vartheta)$ .

2) *Sensitivity of the residual to an input sensor fault*: The residual sensitivity to an input sensor fault,  $f_u$ , is given by the transfer function matrix  $\mathbf{S}_{f_u}$  which dimension is  $ny \times nu$ . The dynamic residual sensitivity is computed as:

$$\begin{aligned} \mathbf{S}_{f_u}(q^{-1}, \vartheta) &= (\mathbf{I} + \mathbf{C}^u(\vartheta)(q\mathbf{I} - \mathbf{A}^u(\vartheta))^{-1})\mathbf{B}^u(\vartheta) \\ &= (\mathbf{I} + \mathbf{H}_r^u(q^{-1}, \vartheta))^{-1}\mathbf{F}_u(\vartheta) \end{aligned} \quad (15)$$

where  $\mathbf{A}^u(\vartheta) = \mathbf{A}(\vartheta) - \mathbf{L}(\vartheta)\mathbf{C}(\vartheta)$ ,  $\mathbf{B}^u = \mathbf{B}(\vartheta) - \mathbf{L}(\vartheta)\mathbf{D}(\vartheta)$ ,  $\mathbf{C}^u(\vartheta) = \mathbf{C}(\vartheta)$ ,  $\mathbf{D}^u(\vartheta) = \mathbf{D}(\vartheta)$  and  $\mathbf{H}_r^u(q^{-1}, \vartheta) = \mathbf{C}^u(q\mathbf{I} - \mathbf{A}^u(\vartheta))\mathbf{B}^u(\vartheta) + \mathbf{D}^u(\vartheta)$ .

In order to perform diagnosis, the algorithm uses a *theoretical fault sensitivity matrix* ( $FSM_{sensit}$ ), see Table I. Each value of this matrix, denoted as  $S_{r_i f_j}$ , contains the sensitivity of the residual  $r_i$  to the fault  $f_j$ . Each value of this matrix, denoted as  $S_{r_i f_j}$ , contains the sensitivity of the residual  $r_i$  to the fault  $f_j$ .

$r_i/f_j$	$f_1$	$f_2$	$\dots$	$f_m$
$r_1$	$S_{11}$	$S_{12}$	$\dots$	$S_{1m}$
$r_2$	$S_{21}$	$S_{22}$	$\dots$	$S_{2m}$
$\vdots$	$\vdots$	$\vdots$	$\vdots$	$\vdots$
$r_n$	$S_{n1}$	$S_{n2}$	$\dots$	$S_{nm}$

TABLE I  
THEORETICAL FAULT SENSITIVITY SIGNATURE MATRIX

Although sensitivity depends on time in case of a dynamic system, here the steady-state value after a fault occurrence is considered as it is also suggested by [3].

In order to perform real time diagnosis, the observed sensitivity  $S_{r_i f_j}^o$  should be computed using the current value of the residual  $r_i(k)$  when a fault  $f(k)$  is detected. But, this requires the knowledge of the fault magnitude or an estimation of it. To solve this problem, this paper attempts to design the diagnosis using the concept of *relative sensitivity* rather than absolute sensitivity given by (3). The observed relative fault sensitivity is defined as

$$S_{r_i, r_l, f_j}^{rel, o} = \frac{S_{r_i f_j}}{S_{r_l f_j}} = \frac{r_i(k)f_j(k)}{r_l(k)f_j(k)} = \frac{r_i(k)}{r_l(k)} \quad (16)$$

where

$$r_l^i = \max_{i=1, \dots, m} (|S_{r_i f_m}|) \quad (17)$$

The residual ( $r_l$ ) for each  $f_j$  to be used as relative factor in Eq. (16), that guarantees the best isolation performance it is based on theoretical sensitivity value from one fault to another, see Eq. (17). Using the concept of relative sensitivity, the theoretical relative fault signature matrix  $FSM_{sensit}^{rel}$  presented in Table II is introduced.

	$f_1$	$f_2$	$\dots$	$f_m$
$r_2/r_l$	$S_{r_2 r_l, f_1}^{rel, t}$	$S_{r_2 r_l, f_2}^{rel, t}$	$\dots$	$S_{r_2 r_l, f_m}^{rel, t}$
$r_3/r_l$	$S_{r_3 r_l, f_1}^{rel, t}$	$S_{r_3 r_l, f_2}^{rel, t}$	$\dots$	$S_{r_3 r_l, f_m}^{rel, t}$
$\dots$	$\dots$	$\dots$	$\dots$	$\dots$
$r_m/r_l$	$S_{r_m r_l, f_1}^{rel, t}$	$S_{r_m r_l, f_2}^{rel, t}$	$\dots$	$S_{r_m r_l, f_m}^{rel, t}$

TABLE II  
THEORETICAL FAULT SIGNATURE MATRIX USING RELATIVE SENSITIVITY RESPECT TO  $r_l$

The diagnostic Algorithm 2 computes in real-time the observed relative sensitivities (16) as a ratio of residuals providing a point vector in the relative sensitivities space. The vector generated will be compared with vectors of theoretical fault places stored into the relative sensitivity matrix  $FSM_{sensit}^{rel}$ . The theoretical fault signature vector with a minimum distance with respect to the fault observed vector is postulated as the possible fault as:

$$\min \{d_{f_1}^s(k), \dots, d_{f_n}^s(k)\} \quad (18)$$

where the distance is calculated using the Euclidean distance between vectors

$$d_{f_n}^s(k) = \sqrt{\left( S_{r_2 r_l, f_1}^{rel, o}(\vartheta_k) - S_{r_2 r_l, f_1}^{rel, t}(\vartheta_k) \right)^2 + \dots + \left( S_{r_m r_l, f_n}^{rel, o}(\vartheta_k) - S_{r_m r_l, f_n}^{rel, t}(\vartheta_k) \right)^2} \quad (19)$$

Algorithm 2 summarizes the fault isolation procedure.

---

#### Algorithm 2 Fault Isolation

---

- 1:  $fault \leftarrow TRUE$
  - 2:  $k \leftarrow k + 1$
  - 3: **while**  $fault = TRUE$  **do**
  - 4:   Obtain input-output data  $\{\mathbf{u}_k, \mathbf{y}_k\}$
  - 5:   Compute the approximated set of estimated outputs, using Algorithm 1 step: 6 to 9.
  - 6:   Compute the Theoretical Sensitivity Dynamic for process output  $y_n$  at  $f_j$ ,  $S_{r_l f_j}^t(\vartheta_k)$
  - 7:   Compute the Observed Sensitivity Dynamic for process output  $y_n$  at  $f_j$ ,  $S_{r_l f_j}^o(\vartheta_k)$
  - 8:   Compute the Euclidean distance between Theoretical and Observed Sensitivity,  $d_{f_n}^s(k) = \{S_{r_l f_n}^t(\vartheta_k), S_{r_l f_n}^o(\vartheta_k)\}$
  - 9:   Fault isolation  $\rightarrow f$
  - 10: **end while**
- 

## V. CASE STUDY

### A. Introduction

In this paper, a PEM FC model developed by [12] is used as case study for fault diagnosis. This model has been modified in a calibration procedure for a commercial fuel cell, (Ballar Nexa<sup>©</sup>) using lqs non linear data fitting from lab data. The overall FC system could be partitioned as: fuel cell stack

and auxiliary components. The auxiliary components are compressor, supply and return manifold, cooling and humidifier. Stack voltage, anode and cathode flow, membrane hydration models belong to fuel cell stack subsystem. Figure 1 presents a conceptual diagram of the FC system.




Fig. 1. PEM FC Process Block diagram

### B. PEM FC Dynamic Model

The non-linear parameter model depends on state variables, which infers a high level of non-linear model, for that reason an observer approach is proposed. This model has the following:

#### Characteristics:

- The law of mass conservation is used for mass balance estimate.
- Physics laws and some empirical equations are used.
- The properties are based on electrochemical, thermodynamic and zero-dimensional fluid mechanics principles.

#### Assumptions:

- Cathode and Anode volume are taken as single volume.
- Perfect temperature control at cooling system.
- Stack temperature is constant.
- The electrochemical reaction at membrane is performed instantaneously.

The resulting dynamic model equation is described by

$$\begin{aligned}
 \dot{\omega}_{cp} &= \frac{1}{J_{cp}\omega_{cp}} (P_{cm} - P_{cp}) \\
 \dot{P}_{om} &= \frac{R_{air}T_{om}}{V_{om}} (W_{ca,o} - W_{om,o}) \\
 \dot{m}_{om} &= W_{ca} - W_{om,o} \\
 \dot{P}_{im} &= \frac{\gamma R_a}{V_{im}} (W_{cp}T_{cp} - W_{im,o}T_{im}) \\
 \dot{m}_{im} &= W_{cp} - W_{sm,o} \\
 \dot{m}_{H_2} &= W_{H_2,i} - W_{H_2,o} - W_{H_2,r} \\
 \dot{m}_{w,an} &= W_{v_{an},i} - W_{v_{an},o} - W_{v_{mbr}} \\
 \dot{m}_{N_2} &= W_{N_2,i} - W_{N_2,o} \\
 \dot{m}_{O_2} &= W_{O_2,i} - W_{O_2,o} - W_{O_2,r} \\
 m_{st}C_{st}\dot{T}_{st} &= \dot{H}_{reac} - P_{elec} - \dot{Q}_{rad} - \dot{Q}_{conv}
 \end{aligned}$$

where the subindex  $i,o$ , represents inlet and outlet flow respectively and subindex  $an, rm, mbr, sm, cp$  means anode, return manifold, membrane, supply manifold and compressor, respectively.

This non-linear model can be transformed into a LPV model in state space form by considering the following definition for

- states:  $x = [\omega_{cp} P_{om} m_{om} P_{im} m_{im} m_{H_2} m_{w,an} m_{N_2} m_{O_2} T_{st}]^T$ .
- inputs:  $u = [I_{st} v_{cm}]^T$  where the scheduling variable is  $I_{st}$ .
- outputs:  $y = [\omega_{cp} rO_2 v_{st} P_{sm}]$  and
- perturbations:  $z = [T_{amb}]$ .

The units of all these variables are in compatible magnitudes (kRPM, gr, volt bar, amp).

### C. LPV Model Analysis

Since the model is a highly non-linear model, it is difficult to obtain a explicit dynamic model with independence of the parameter with the operating point,  $I_{st}$ . To face this problem the problem an LPV model is an alternative way to solve this problem. The structure of the model in LPV form has the following structure

$$\begin{aligned}
 A &= \begin{bmatrix} a_{11} & 0 & 0 & a_{14} & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & a_{22} & a_{23} & a_{24} & a_{25} & 0 & 0 & a_{28} & a_{29} & a_{210} \\ 0 & a_{32} & 0 & a_{34} & a_{35} & 0 & 0 & a_{38} & a_{39} & a_{310} \\ a_{41} & 0 & 0 & a_{44} & a_{45} & 0 & 0 & a_{48} & a_{49} & a_{410} \\ a_{51} & 0 & 0 & a_{54} & 0 & 0 & 0 & a_{58} & a_{59} & a_{510} \\ 0 & 0 & 0 & a_{64} & 0 & a_{66} & a_{67} & 0 & 0 & a_{610} \\ 0 & 0 & 0 & a_{74} & 0 & a_{76} & a_{77} & 0 & 0 & a_{710} \\ 0 & a_{82} & 0 & a_{84} & a_{85} & 0 & 0 & a_{88} & a_{89} & a_{810} \\ 0 & a_{92} & 0 & a_{94} & a_{95} & 0 & 0 & a_{98} & a_{99} & a_{910} \\ 0 & 0 & 0 & 0 & 0 & a_{106} & a_{107} & 0 & a_{109} & 0 \end{bmatrix}; \\
 C &= \begin{bmatrix} c_{11} & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & c_{24} & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & c_{34} & c_{35} & 0 & 0 & c_{38} & c_{39} & c_{310} \\ 0 & 0 & 0 & 0 & 0 & c_{46} & c_{47} & c_{48} & c_{49} & c_{410} \end{bmatrix}; \\
 B &= \begin{bmatrix} b_{11} & b_{12} \\ 0 & 0 \\ 0 & 0 \\ 0 & 0 \\ 0 & 0 \\ b_{71} & 0 \\ b_{81} & 0 \\ 0 & 0 \\ b_{91} & 0 \\ b_{101} & 0 \end{bmatrix}; D = \begin{bmatrix} 0 & 0 \\ d_{31} & 0 \\ d_{41} & 0 \end{bmatrix}
 \end{aligned}$$

subsection Faulty PEM FC scenarios implementation

In order to test the proposed methodology in the PEM FC system, a set of commons possible fault in the sensors was selected and implemented in simulation as a Fault Generator Block. Through this block it is possible to select and simulate the effects that cause each of the proposed faults over the Nexa<sup>©</sup> fuel cell. Each fault acts over a specific output sensor as additive fault. Note that interaction could appear in fuel cell dynamic when the fault acts over the system because since fault changes the process dynamics making the fault diagnosis process a non simple issue. The Table III describe the set of faults which were considered as additive and abrupt faults.

### D. Results

Using Eq. (14) and evaluating it in steady state, then

$$\begin{aligned}
 S_{fy}(\infty) &= \lim_{q \rightarrow 1} S_{fy}(q^{-1}, \vartheta) \\
 &= \left( I + C(\vartheta) (I - A(\vartheta))^{-1} L(\vartheta) \right)^{-1} F_y(\vartheta)
 \end{aligned} \tag{20}$$

From Eq. (20) Table IV is computed

ID	Fault Description
$f_1$	The speed sensor ( $\omega_{cp}$ ) presents suddenly an offset value. <i>step</i> of 6 units( $kRPM$ ).
$f_2$	The supply manifold pressure ( $P_{sm}$ ) measurement suffers a suddenly offset. <i>Step</i> of 0.01( $bar$ )
$f_3$	Suddenly change in the Oxygen ratio measurement because of a sensor degradation. <i>Ramp</i> with <i>slop</i> of 0.5
$f_4$	The stack Itage ( $v_{st}$ ) measurement suffers a suddenly an offset . <i>step</i> of 4 ( <i>Volts</i> )

TABLE III

DESCRIPTION OF THE ADDITIVE FAULT SCENARIOS IMPLEMENTED IN FGB.

	$f_1$	$f_2$	$f_3$	$f_4$
$r_1$	7.939483	$5.76E-05$	$6.65E-05$	0.002366
$r_2$	$-2.83E-05$	0.009996	$-6.42E-06$	-0.00019
$r_3$	-0.03957	0.009236	0.510927	0.373165
$r_4$	0.265891	-0.07013	-0.08645	1.115084

TABLE IV

THEORETICAL FAULT SENSITIVITY SIGNATURE MATRIX

Based on the values computed in Table IV, its more clear if the range of study for fault sensitivity is  $[-1, 1]$ . For that reason a scaling operation is introduced as Eq. (21), then Table V is obtained.

$$r_i^s = \frac{r_i}{\sqrt{\sum_{i=1}^n r_i^2}} \quad (21)$$

	$f_1$	$f_2$	$f_3$	$f_4$
$r_1^s$	0.999	0.0008	0.000128	0.00201
$r_2^s$	$-3.6E-6$	0.1399	$-1.2E-5$	-0.00016
$r_3^s$	-0.005	0.12928	0.9859	0.3173
$r_4^s$	0.0334	-0.98169	-0.16682	0.9483

TABLE V

THEORETICAL FAULT SENSITIVITY SIGNATURE MATRIX SCALED VALUES

Using the values from Table V and selecting the ratio factor,  $r_l$ , for each  $f_j$  fault using the criteria introduced in Eq. (17).

$$r_l^j = [r_1, r_4, r_3, r_4]$$

With the last information it is possible to compute the theoretical relative sensitivity matrix, which will be stored in the memory of the isolation algorithm.

$f_1$		$f_2$		$f_3$		$f_4$	
$r_2/r_1$	$-3.6E-06$	$r_1/r_4$	$-0.00082$	$r_1/r_3$	$0.00013$	$r_1/r_4$	$0.002122$
$r_3/r_1$	$-0.00498$	$r_2/r_4$	$-0.14253$	$r_2/r_3$	$-1.3E-05$	$r_2/r_4$	$-0.00017$
$r_4/r_1$	$0.03349$	$r_3/r_4$	$-0.13169$	$r_4/r_3$	$-0.16919$	$r_3/r_4$	$0.334651$

TABLE VI

THEORETICAL RELATIVE FAULT SENSITIVITY SIGNATURE MATRIX.

In order to test the proposed methodology, an output sensor fault,  $f_1$  is simulated. Using Eq. (14) and Table VI it is possible to know the Euclidian distance at each  $k$  from Eq. (19) for each fault in its space of residual ratios.




Fig. 2. Real and estimated output variable

Figure 2 shows the scheduling variables, process outputs, estimated model output and the associated residual and thresholds. The plant suffers the fault  $f_1$  at  $k = 80$ . Fault detection process is performed online. At time  $k = 82$  the plant output,  $\omega_{cp}$ , cross one of the threshold, then the process isolation is performed. Figure 3 shows the Euclidean distance from observed relative residuals to relative sensitivity matrix already stored in the memory of the isolation algorithm. Note that computing of the dynamic theoretical relative sensitivity, improves the fault isolation process. Here the fault with the minimum distance is the fault presented in the  $\omega_{cp}$  sensor,  $f_1$ .




Fig. 3. Dynamic Euclidian Distance

## VI. CONCLUSION

In this paper, a new LPV model-based fault diagnosis methodology based on the relative fault sensitivity has been presented and tested. An advantage of this new methodology is twofold: first, the variation of the dynamics with the operating point is considered by using an LPV observer when generating residuals. Second, a fault isolation algorithm based on the relative fault sensitivity concept is proposed. This method allows isolating faults that are not isolable considering only a binary (or a sign) fault signature matrix. To prove this methodology, a PEM fuel cell case study well-known in the literature has been used. The case study was modified to include a set of possible fault scenarios that try to reflect the most common faults. All the considered faults have been tested with the new diagnosis methodology, which has diagnosed correctly all of them.

## VII. ACKNOWLEDGMENTS

This work has been partially funded by the grant CICYT HYFA DPI2008-01996 of Spanish Ministry of Education and by a grant from Consejo Nacional de Ciencia y Tecnologia (CONACyT), México. The authors wish also to thank to the *Instituto de Robotica i Informatica Industrial (IRI/UPC-CSIC)* for its *knowhow* sharing, specially to J. Riera, M. Serra and D. Feroldi.

## REFERENCES

- [1] M. Blanke, M. Kinnaert, J. Lunze, and M. Staroswiecki, *Diagnosis and Fault-Tolerant Control*. Springer-Verlag Berlin Heidelberg, 2003.
- [2] D. Luenberger, "An introduction to observers." *IEEE Automatic Control*, vol. 16, no. 6, pp. 596–602, 1971.
- [3] J. Gertler, *Fault Detection and Diagnosis in Engineering Systems*. New York: Marcel Dekker, 1998.
- [4] M. Staroswiecki and G. Comtet-Varga, "Analytical redundancy relations for fault detection and isolation algebraic dynamic systems," *Automatica*, vol. 37, no. 5, pp. 687–699, 2001.
- [5] I. R., "Model-based fault-detection and diagnosis-status and applications," *Annual Reviews in Control*, vol. 29, no. 1, pp. 71–85, 2005.
- [6] J. Chen and R. Patton, *Robust Model-Based Fault Diagnosis for Dynamic Systems*. Marcel Dekker, 1999.
- [7] C. Rayment and S. Sherwin, "Introduction to fuel cell technology." in *University of Notre Dame*, 2003, department of Aerospace and Mechanical Engineering.
- [8] B. P., T. D., Y. Y., and P. R., "From differential equations to pdc controller design via numerical transformation," *Computers in Industry*, vol. 51, pp. 281–297, 2003.
- [9] M.-S. R. and J. T. A., *Multiple model approaches to modeling and control*, 2nd ed. London, Taylor and Francis., 1997.
- [10] M. Chilali and P. Gahinet, " $h_\infty$  design with pole placement constraints: an LMI approach," *IEEE Transactions on Automatic Control*, vol. 41, no. 3, pp. 358–367, 1996.
- [11] V. Puig, J. Quevedo, T. Escobet, and J. Meseguer, "Towards a better integration of passive robust interval-based fdi algorithms," *6th IFAC SAFEPROCESS*, vol. 16, no. 5, 2006.
- [12] J. Pukrushpan, H. Peng, and A. Stefanopoulou, "Pem fc dynamic system," *Journal of Dynamics Systems, Measurement, and Control*, vol. 126, pp. 14–25, 2002.