

Active fault detection based on set-membership approach for uncertain discrete-time systems

Jing Wang^{1,2}  | Yuru Shi² | Meng Zhou¹  | Ye Wang³  | Vicenç Puig⁴ 

¹School of Electrical and Control Engineering, North China University of Technology, Beijing, China

²College of Information Science and Technology, Beijing University of Chemical Technology, Beijing, China

³College of Automation, Harbin Engineering University, Harbin, China

⁴Advanced Control Systems Research Group at Institut de Robotica, CSIC-UPC, Universitat Politècnica de Catalunya-BarcelonaTech, Barcelona, Spain

Correspondence

Meng Zhou, School of Electrical and Control Engineering, North China University of Technology Beijing, China.
Email: zhoumeng@ncut.edu.cn

Funding information

Research foundation for talents of NCUT, Grant/Award Numbers: 213051360020XN173/017, 110051360020XN092; National Natural Science Foundation of China, Grant/Award Numbers: 51805021, 61973023, 61573050; the Fundamental Research Funds for the Central Universities, Grant/Award Number: XK1802-4

Summary

Active fault detection facilitates determination of the fault characteristics by injecting proper auxiliary input signals into the system. This article proposes an observer-based on-line active fault detection method for discrete-time systems with bounded uncertainties. First, the output including disturbances, measurement noise and interval uncertainties at each sample time is enclosed in a zonotope. In order to reduce the conservativeness in the fault detection process, a zonotopic observer is designed to estimate the system states allowing to generate the output zonotopes. Then, a proper auxiliary input signal is designed to separate the output zonotopes of the faulty model from the healthy model that is injected into the system to facilitate the detection of small fault. Since the auxiliary input signal generation leads to a nonconvex optimization problem, it is transformed into a mixed integer quadratic programming problem. Finally, a case study based on a DC motor is used to show the effectiveness of the proposed method.

KEYWORDS

active fault detection, interval uncertainty, set-membership, small fault, zonotope

1 | INTRODUCTION

In modern industries, operational safety and product quality of systems are important issues. If a fault occurs, it will not only affect the quality of the product, but it can also consequently bring security risks to the systems and operators. Therefore, fault diagnosis (FD)^{1,2} plays a crucial role in industrial processes. Over the past decades, an important number of FD methods have been developed. These methods can be classified into passive³ and active FD⁴ depending if the system input is manipulated or not. In passive FD, the system is monitored using the system inputs and outputs without manipulation. Passive FD approaches can be divided into model-based methods,^{5,6} knowledge-based methods,⁷ and data-driven methods.^{8,9} On the other hand, the key idea of active FD is to enhance the output separability of the healthy model from the faulty ones by manipulating the input signal.¹⁰ In this way, the fault characteristics become more clearly such that smaller faults can be detected. For this reason, active FD has attracted increasing researcher attention in recent years. Active FD methods mainly include deterministic and probabilistic methods depending on the underlying assumptions regarding system noise and disturbance.¹¹ The deterministic methods assume that the noise and disturbance can be modeled as an unknown but bounded signal. Examples of such methods are the integrated controller and detector

design method and the guaranteed FD approach.^{12,13} Probabilistic methods assume that uncertainties such as noise and disturbance affecting the system can be represented by random variables with known probability density functions. Then, fault detection is based on probabilistic methods such as statistical tests¹⁴ or the Bayesian approach.¹⁵

Most of the existing active FD methods assume that the noise and system disturbance follow a Gaussian distribution. However, such a prior knowledge of the probability distribution of the noise and disturbance in the actual system is difficult to be satisfied in practice.¹⁶ On the other hand, the active set-membership methods FD generally do not assume any prior information regarding measurement noise and process disturbance distribution of the system except that they are unknown but the upper and lower bounds are known. The set-membership approaches allow to establish the separability conditions between faulty and non-faulty case in a guaranteed way by using the bounded description of the uncertainty and noises/disturbances. These conditions are then used to design an auxiliary input signal guaranteeing the separability of the healthy from the faulty modes improving FD performance. Therefore, compared with other active fault detection methods, the set-membership approach provides framework for active fault detection with separability guarantees. Set-membership approach can compute a set containing all the possible system outputs/states that are consistent with the unknown but bounded disturbances, modeling uncertainties, and measurement noise. Hence, it is a suitable technique for state estimation when a system is modeled by some unknown but bounded disturbances. The set-membership approach considers the system disturbance and measurement noise bounded by means of a set. Several alternative set descriptions have been considered in the literature including ellipsoids, intervals, polytopes, and zonotopes.

In the field of guaranteed active FD, ellipsoidal sets have been widely used for bounding uncertainty. For example, uncertainties such as measurement noise and process disturbance of system are expressed in ellipsoidal form. Then, active FD is realized by designing auxiliary input signals off-line¹⁷ or on-line.¹⁸ Compared with ellipsoids, zonotopes produces less conservative results when designing auxiliary input signals. Moreover, they can be used not only in the design of auxiliary input signals for open-loop systems,¹⁹ but also for closed-loop systems.²⁰ In addition, the idea of active FD based on set-membership approach is also used for active fault isolation²¹ and multimodel separation.²²

Generally, the existing active FD methods based on the set-membership approach mainly use the idea of the set theory to bound system outputs using sets and model.²³ The use of observer design method cannot only used to reduce the size of the system output sets but to guarantee the convergence. Therefore, in this article, the zonotopic Kalman filter method is used, which reduces the size of the system output sets. It should be mentioned that the uncertain system contains not only process disturbance and measurement noise, but also the uncertainties of system parameters, increasing the size of the minimum detectable faults. However, to the best knowledge of the authors', little attention has been paid on active fault detection based on set-membership method for system with parametric uncertainty. In the work of Zhou et al.,²⁴ an interval fault estimation approach is proposed for discrete-time linear parameter-varying systems, however, it deals with the problem of passive fault detection. Motivated by the work,²⁴ in our work, we mainly focused on designing a proper auxiliary input signal for discrete-time system with parametric uncertainties to reduce the size of the minimum detectable faults.

The main contributions of this article can be summarized as follows: First, an active fault detection is proposed based on zonotopic Kalman filter observer for discrete-time system with bounded uncertainties. Following the earlier work regarding active FD based on set-membership approach, we first apply this method to discrete-time system with parametric uncertainty, in which an auxiliary input signal is designed to separate the output zonotopes in the healthy case from the output zonotopes in the faulty case. Besides, in order to reduce the conservatism of auxiliary input signal design process, a zonotopic observer is designed to estimate the system output zonotope. Finally, the proposed approach is assessed using a case study based on a DC motor showing an improved detection in case of small faults.

The remainder of the article is organized as follows. First, in Section 2, some preliminaries and the statement of the problem formulation used in this article are introduced. Then, the zonotopic observer is designed to reduce the output set size in Section 3. An optimal auxiliary input signal is obtained by using output sets in Section 4. In Section 5, a DC motor is used as a case study and the simulation results show the effectiveness of the proposed method. Finally, the conclusion of this article is introduced in Section 6.

2 | PRELIMINARIES AND PROBLEM FORMULATION

2.1 | Preliminaries

Definition 1. The r order zonotope \mathcal{Z} is defined as

$$\mathcal{Z} = p + \sum_{j=1}^r \alpha_j h_j = p \oplus H\mathbf{B}^r = \langle p, H \rangle, \quad (1)$$

where $p \in \mathbb{R}^n$ and $H = \{h_1, h_2, \dots, h_r\} \in \mathbb{R}^{n \times r}$ are the center and the generator matrix of \mathcal{Z} , respectively. $\mathbf{B}^r = [-1, +1]^r$ is a unitary hypercube and $\|\alpha\|_\infty \leq 1$.

Property 1. Considering an interval $[a_1, a_2]$, $\text{mid}[a_1, a_2] = \frac{a_1+a_2}{2}$ and $\text{rad}[a_1, a_2] = \frac{a_2-a_1}{2}$ are the center and radius of the interval, respectively.

Property 2. Given an interval matrix $[A]$, where $A_{ij} = \{a_{ij} : a_{1,tj} \leq a_{ij} \leq a_{2,tj}\}$. The center and radius of the interval matrix are $\text{mid}[A]_{ij} = \frac{a_{1,tj}+a_{2,tj}}{2}$ and $\text{rad}[A]_{ij} = \frac{a_{2,tj}-a_{1,tj}}{2}$, respectively.

Property 3. The Minkowski sum of two zonotopes $\mathcal{Z}_1 = p_1 \oplus H_1 \mathbf{B}^{r_1}$ and $\mathcal{Z}_2 = p_2 \oplus H_2 \mathbf{B}^{r_2}$ is defined as

$$\mathcal{Z}_1 \oplus \mathcal{Z}_2 = \langle p_1, H_1 \rangle \oplus \langle p_2, H_2 \rangle = (p_1 + p_2) \oplus \begin{bmatrix} H_1 & H_2 \end{bmatrix} \mathbf{B}^{r_1+r_2}. \quad (2)$$

Property 4. The product of matrix M and zonotope $\mathcal{Z} = \langle p, H \rangle$ is calculated as

$$M\mathcal{Z} = \langle Mp, MH \rangle. \quad (3)$$

Property 5 (25). Frobenius radius of the generator matrix H can be used as an indicator to measure the size of the zonotope. It is expressed as

$$J = \sqrt{\text{tr}(H^T H)} = \sqrt{\text{tr}(H H^T)}, \quad (4)$$

where $\text{tr}(\cdot)$ is the matrix trace.

Property 6 (26). Considering a family of zonotopes represented by $\mathcal{Z} = p \oplus [H] \mathbb{B}^r$, where $p \in \mathbb{R}^n$ is a real vector, $[H] \in \mathbb{I}^{n \times r}$ is an interval matrix, \mathbb{I} is defined as a set of real compact intervals. A family of zonotopes can be bounded by an outer approximation, as follows

$$\mathcal{Z} = p \oplus [\text{mid}[H] \quad \text{rs}(\text{rad}[H])] \mathbf{B}^{r+n}. \quad (5)$$

where $\text{rs}(H) = \text{diag}(\sum_{j=1}^r |H_{n,j}|)$.

Property 7 (27). The product of an interval $[A]$ and a matrix B denoted by $[A]B$ is bounded by a zonotope whose center and radius are $\text{mid}([A]B) = (\text{mid}[A])B$ and $\text{rad}([A]B) = (\text{mid}[A])|B|$, respectively. $|B|$ is the absolute value of each element in the matrix B .

Lemma 1 (28). A zonotope \mathcal{Z} can be bounded by a minimal box $\square \mathcal{Z}$ known as interval hull

$$\mathcal{Z} \subset \square \mathcal{Z} = p \oplus \text{rs}(H) \mathbf{B}^r. \quad (6)$$

Lemma 2 (29). Let consider the r -order zonotope $\mathcal{Z} = p \oplus H \mathbf{B}^r \subset \mathbb{R}^n$ and the integer $n \leq s \leq r$. The column vector of the matrix H is arranged in descending order of the Euclidean norm to obtain the matrix \bar{H} . \mathcal{Z} can be included in a s -order $\bar{\mathcal{Z}}$, that is

$$\mathcal{Z} \subseteq \bar{\mathcal{Z}} = p \oplus \begin{bmatrix} \bar{H}_1 & Q \end{bmatrix} \mathbf{B}^s, \quad (7)$$

where \bar{H}_1 the first $s - n$ column vectors of \bar{H} , \bar{H}_2 the last n column vectors of \bar{H} . Q is the box containing \bar{H}_2 obtained by Lemma 1, that is

$$Q_{it} = \sum_{j=1}^r |\bar{H}_2|_{tj}, t = 1, 2, \dots, n. \quad (8)$$

Lemma 3 (30,31). Given two zonotopes $\mathcal{X} = \langle a_x + b_x, H_x \rangle$ and $\mathcal{Y} = \langle a_y + b_y, H_y \rangle$, $\mathcal{X} \cap \mathcal{Y} = \emptyset$ if and only if

$$a_y - a_x \notin \langle b_x, H_x \rangle \oplus \langle -b_y, H_y \rangle. \quad (9)$$

2.2 | Problem formulation

Let consider the class of uncertain discrete-time systems as:

$$\begin{cases} x_{k+1}^{[i]} = A^{[i]}(\theta)x_k^{[i]} + B^{[i]}u_k + B_\omega^{[i]}\omega_k^{[i]}, \\ y_k^{[i]} = C^{[i]}x_k^{[i]} + D_v^{[i]}v_k^{[i]}, \quad i = 0, 1, 2, \dots, q, \end{cases} \quad (10)$$

where i is the system model: the case $i = 0$ corresponds to the healthy model, otherwise, the other cases correspond to the faulty models, where q denotes the total number of models. $x_k \in \mathbb{R}^{n_x}$, $u_k \in \mathbb{R}^{n_u}$, $y_k \in \mathbb{R}^{n_y}$ are state, input, and output of the system at sample time k , respectively. $\omega_k \in \mathbb{R}^{n_\omega}$ and $v_k \in \mathbb{R}^{n_v}$ represent the process disturbance and measurement noise of the system, respectively. $A^{[i]}(\theta)$, $B^{[i]}$, $C^{[i]}$, $B_\omega^{[i]}$, $D_v^{[i]}$ are matrices of appropriate dimensions. θ is a vector that contains the uncertain parameters of the system that are assumed to be unknown but bounded. $A(\theta)$ is an uncertain matrix that can be defined as an interval matrix $[A]$.

This article assumes that the initial state, process disturbance, and measurement noise of the system are unknown but bounded as follows

$$\begin{aligned} x_0^{[i]} &\in \mathcal{X}_0^{[i]} = \langle p_0^{[i]}, H_0^{[i]} \rangle, \\ \omega_k^{[i]} &\in \mathcal{W}^{[i]} = \langle 0, H_\omega^{[i]} \rangle, \\ v_k^{[i]} &\in \mathcal{V}^{[i]} = \langle 0, H_v^{[i]} \rangle, \end{aligned} \quad (11)$$

where $\mathcal{X}_0^{[i]}$, $\mathcal{W}^{[i]}$, and $\mathcal{V}^{[i]}$ are the zonotopes bounding the initial state, process disturbance, and measurement noise, respectively. The output zonotopes of the system can be obtained by propagating the uncertainty using the zonotope properties and the system model (10).

Remark 1. As discussed in Reference 32, because of the parametric uncertainty, process disturbances, and noise, there will always be a minimum fault size that will be not be detectable (ie, the measured output will be in the healthy output set $\mathcal{Y}^{[0]}$ even in the fault presence) or isolable (ie, $\mathcal{Y}^{[i]} \cap \mathcal{Y}^{[j]} \neq \emptyset, i \neq j, i, j \in \{1, 2, \dots, q\}$).

To reduce the size of the minimum detectable/isolable faults, active FD based on the auxiliary input signal design relies on designing an auxiliary input signal, and injecting it into the system to improve the fault separability. Active FD based on set-membership approaches aims at designing auxiliary input signals to separate the output sets of different models, that is

$$\mathcal{Y}^{[i]} \cap \mathcal{Y}^{[j]} = \emptyset, i \neq j, i, j \in \{0, 1, 2, \dots, q\}, \quad (12)$$

where $\mathcal{Y}^{[i]}$ and $\mathcal{Y}^{[j]}$ are the output sets of model i and model j , respectively.

Figure 1 shows the process of active fault detection based on set-membership method. The healthy output set and faulty output set when the auxiliary input signal is not added to the system are shown in Figure 1A. When the healthy and faulty models intersect, it is impossible to judge whether the system is faulty or not. When the optimal auxiliary input signal is injected into the system, the two sets are separated as shown in Figure 1B.

The main objective of this article is to design an optimal input signal such that the healthy output zonotope can be separated from the faulty output zonotope for discrete-time systems with parametric uncertainty.




FIGURE 1 Process of active fault detection

3 | BOUNDING OUTPUT SET USING ZONOTOPIC OBSERVERS

The diagram of the approach proposed in this article is depicted in Figure 2. In this figure, u_{k-1} is the auxiliary input signal, y_k is the system output, $\hat{x}_k^{[0]}$ and $\hat{x}_k^{[1]}$ are the state estimations obtained using the healthy and faulty models, respectively. $\mathcal{Y}_k^{[0]}$ and $\mathcal{Y}_k^{[1]}$ are the output zonotopes estimated using the healthy and faulty models, respectively. In order to reduce the conservativeness, a zonotopic observer is designed for estimating the output zonotope instead of using the system model (10) as usually done in the active fault detection literature. Then, an auxiliary input signal is designed to separate the output zonotopes of the healthy model from the output zonotopes of the faulty model. Finally, the input signal is injected into the system to obtain the fault detection results.

The state observer mainly corrects the state of the system using the error between the measured output and the observed output. Therefore, the size of the output set is tighter by using a state observer leading to less conservative results than using the system model (10). In this section, a zonotopic observer is first designed for (10). Then, the size of the output zonotopes is analyzed and it is demonstrated that the zonotope size can be reduced with the proposed observer-based design method.

3.1 | Zonotopic observer design

Based on the zonotopic Kalman filter approach,³³ the observer for the system (10) has the following structure

$$\hat{x}_{k+1}^{[i]} = A^{[i]}(\theta)\hat{x}_k^{[i]} + B^{[i]}u_k + B_\omega^{[i]}\omega_k^{[i]} + L_k^{[i]}(y_k - C^{[i]}\hat{x}_k^{[i]} - D_v^{[i]}v_k^{[i]}), i = 0, 1, 2, \dots, q. \quad (13)$$

where $\hat{x}_k^{[i]}$ is the estimate of the state at time k , $L_k^{[i]}$ is the time-varying observer gain, and y_k is the system output.

Theorem 1. Assume that the system state estimation at time sample k satisfies $\hat{x}_k^{[i]} \in \mathcal{X}_k^{[i]} = \langle p_k^{[i]}, H_k^{[i]} \rangle$. Then, the state at sample time $k + 1$ is given by

$$\hat{x}_{k+1}^{[i]} \in \mathcal{X}_{k+1}^{[i]} = \langle p_{k+1}^{[i]}, H_{k+1}^{[i]} \rangle, \quad (14)$$

where

$$\begin{cases} p_{k+1}^{[i]} = \text{mid}([A^{[i]}] - L_k^{[i]}C^{[i]})p_k^{[i]} + B^{[i]}u_k + L_k^{[i]}y_k \\ H_{k+1}^{[i]} = \begin{bmatrix} \text{mid}([A^{[i]}] - L_k^{[i]}C^{[i]})\bar{H}_k^{[i]} \\ \text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]}C^{[i]})|p_k^{[i]}) \end{bmatrix} \quad \text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]}C^{[i]})|p_k^{[i]}) \quad B_\omega^{[i]}H_\omega^{[i]} \quad \left(L_k^{[i]}D_v^{[i]}H_v^{[i]} \right), \end{cases} \quad (15)$$

$p_{k+1}^{[i]} \in \mathbb{R}_x^n$, $H_{k+1}^{[i]} \in \mathbb{R}_{x \times r_x}^{n \times r_x}$, $\bar{H}_{k+1}^{[i]}$ represents the generator matrix after the zonotope reduction using Lemma 2 at sample time $k + 1$.




FIGURE 2 Schematic diagram of the proposed approach [Colour figure can be viewed at wileyonlinelibrary.com]

Proof. According to (13) and taking into account the noise and disturbances bounds (11), the zonotope $\mathcal{X}_{k+1}^{[i]}$ can be rewritten as

$$\begin{aligned}
\hat{\mathbf{x}}_{k+1}^{[i]} \in \mathcal{X}_{k+1}^{[i]} &= [A^{[i]}]\mathcal{X}_k^{[i]} \oplus B^{[i]}u_k \oplus B_\omega^{[i]}\mathcal{W}^{[i]} \oplus L_k^{[i]}y_k \oplus (-L_k^{[i]}\mathcal{X}_k^{[i]}) \oplus (-L_k^{[i]}D_v^{[i]}\mathcal{V}^{[i]}) \\
&= ([A^{[i]}] - L_k^{[i]}C^{[i]}) \odot \langle p_k^{[i]}, H_k^{[i]} \rangle \oplus B^{[i]}u_k \\
&\quad \oplus L_k^{[i]}y_k \oplus [B_\omega^{[i]} \odot \langle 0, H_\omega^{[i]} \rangle] \oplus [(-L_k^{[i]}D_v^{[i]}) \odot \langle 0, H_v^{[i]} \rangle] \\
&= (([A^{[i]}] - L_k^{[i]}C^{[i]})p_k^{[i]} + B^{[i]}u_k + L_k^{[i]}y_k) \\
&\quad \oplus \begin{bmatrix} ([A^{[i]}] - L_k^{[i]}C^{[i]})H_k^{[i]} & B_\omega^{[i]}H_\omega^{[i]} & L_k^{[i]}D_v^{[i]}H_v^{[i]} \end{bmatrix}.
\end{aligned} \tag{16}$$

Using properties of the zonotope and Lemma 2, the center of the state zonotope and the generator matrix can be obtained at sample time $k + 1$. ■

In this article, we mainly will use the output set that is consistent with the unknown but bounded parametric uncertainty, disturbances, and noise. Then, from the zonotope that bounds the states (14), the zonotope that bounds the estimated output $\mathcal{Y}_{k+1}^{[i]}$ can be obtained using (13) as follows

$$\begin{aligned}
y_{k+1}^{[i]} \in \mathcal{Y}_{k+1}^{[i]} &= C^{[i]}\mathcal{X}_{k+1}^{[i]} \oplus D_v^{[i]}\mathcal{V}^{[i]} \\
&= [C^{[i]} \odot \langle p_{k+1}^{[i]}, H_{k+1}^{[i]} \rangle] \oplus [D_v^{[i]} \odot \langle 0, H_v^{[i]} \rangle] \\
&= \langle C^{[i]}p_{k+1}^{[i]}, \begin{bmatrix} C^{[i]}H_{k+1}^{[i]} & D_v^{[i]}H_v^{[i]} \end{bmatrix} \rangle.
\end{aligned} \tag{17}$$

Therefore, the center and radius of output zonotope can be obtained

$$\begin{cases} p_{y,k+1}^{[i]} = C^{[i]}p_{k+1}^{[i]}, \\ H_{y,k+1}^{[i]} = \begin{bmatrix} C^{[i]}H_{k+1}^{[i]} & D_v^{[i]}H_v^{[i]} \end{bmatrix} \end{cases} \tag{18}$$

where $p_{y,k+1}^{[i]} \in \mathbb{R}^{n_y}$, $H_{y,k+1}^{[i]} \in \mathbb{R}^{n_y \times r_y}$.

According to Reference 28, given an observer such as (13), the optimal time-varying gain that minimizes the size of zonotope, measured by means of the Frobenius norm of the zonotope segment matrix as

$$(J_k^{[i]})^2 = \text{tr}((H_{k+1}^{[i]})^T H_{k+1}^{[i]}), \tag{19}$$

can be obtained as follows

$$\begin{aligned}
L_k^{[i]} &= \text{mid}([A^{[i]}])K_k^{[i]}, \\
K_k^{[i]} &= G_k^{[i]}(S_k^{[i]})^{-1}, \\
G_k^{[i]} &= P_k^{[i]}(C^{[i]})^T, \\
S_k^{[i]} &= C^{[i]}P_k^{[i]}(C^{[i]})^T + Q_v^{[i]}, \\
P_k^{[i]} &= \overline{H}_k^{[i]}(\overline{H}_k^{[i]})^T, \\
Q_v^{[i]} &= D_v^{[i]}H_v^{[i]}(H_v^{[i]})^T(D_v^{[i]})^T.
\end{aligned} \tag{20}$$

The optimal gain (21) is derived considering that the size of the output zonotope (20) is minimized when $\frac{\partial (J_k^{[i]})^2}{\partial L_k^{[i]}} = 0$ based on the results in Combastel et al.³⁴

3.2 | Analysis of the size of output zonotopes

As previously discussed, the reduction of the size of the minimum detectable/isolable faults can be achieved by means of the design of the adequate auxiliary input signal such that the output zonotopes of the different models do not overlap.

However, when the overlapping is important, the size of the auxiliary input signal to be used should be large to separate the output zonotope of the different models, disturbing the desired behavior of the system. Therefore, in order to obtain a small auxiliary input signal, the size of the output zonotope should be as smaller as possible.

Theorem 2. Consider the system (10). The size of the output zonotope at time $k + 1$, measured by means of (20), using the observer (13) with optimal gain (21) is smaller than the output zonotope obtained directly using the system model (10),

$$(J_{k+1})^2 \leq (\tilde{J}_{k+1})^2, \quad (21)$$

where $(J_{k+1})^2$ and $(\tilde{J}_{k+1})^2$ denote, respectively, the size of the output zonotope with and without observer.

Proof. The size of the output zonotope obtained with the observer can be measured by means of the Frobenius norm of the zonotope segment matrix (Property 5)

$$\begin{aligned} (J_{k+1})^2 &= \text{tr}((H_{y,k+1}^{[i]})^T H_{y,k+1}^{[i]}) = \text{tr}((\text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) H_k^{[i]})^T \text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) H_k^{[i]} \\ &\quad + (\text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]} C^{[i]})) | H_k^{[i]} |))^T (\text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]} C^{[i]})) | H_k^{[i]} |)) \\ &\quad + (\text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]} C^{[i]})) | p_k^{[i]} |))^T (\text{rs}(\text{rad}([A^{[i]}] - L_k^{[i]} C^{[i]})) | p_k^{[i]} |)) \\ &\quad + (B_\omega^{[i]} H_\omega^{[i]})^T B_\omega^{[i]} H_\omega^{[i]} + (L_k^{[i]} D_v^{[i]} H_v^{[i]})^T L_k^{[i]} D_v^{[i]} H_v^{[i]}). \end{aligned} \quad (22)$$

Using the properties of interval matrices, it follows that

$$\begin{aligned} \text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) &= \text{mid}([A^{[i]}]) - L_k^{[i]} C^{[i]}, \\ \text{rad}([A^{[i]}] - L_k^{[i]} C^{[i]}) &= \text{rad}([A^{[i]}]). \end{aligned} \quad (23)$$

Therefore,

$$\begin{aligned} &(\text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) H_k^{[i]})^T \text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) H_k^{[i]} \\ &= (H_k^{[i]})^T (\text{mid}([A^{[i]}]) - L_k^{[i]} C^{[i]})^T (\text{mid}([A^{[i]}]) - L_k^{[i]} C^{[i]}) H_k^{[i]} \\ &= (H_k^{[i]})^T (\text{mid}([A^{[i]}]))^T \text{mid}([A^{[i]}]) H_k^{[i]} - (H_k^{[i]})^T (L_k^{[i]} C^{[i]})^T \text{mid}([A^{[i]}]) H_k^{[i]} \\ &\quad - (H_k^{[i]})^T (\text{mid}([A^{[i]}]))^T L_k^{[i]} C^{[i]} H_k^{[i]} + (H_k^{[i]})^T (L_k^{[i]} C^{[i]})^T L_k^{[i]} C^{[i]} H_k^{[i]}. \end{aligned} \quad (24)$$

We can proceed similarly to measure the size of output zonotope without observer

$$\begin{aligned} (\tilde{J}_{k+1})^2 &= \text{tr}((\tilde{H}_{y,k+1}^{[i]})^T \tilde{H}_{y,k+1}^{[i]}) \\ &= \text{tr}((\text{mid}([A^{[i]}]) \tilde{H}_k^{[i]})^T \text{mid}([A^{[i]}]) \tilde{H}_k^{[i]} + (\text{rs}(\text{rad}([A^{[i]}]) | \tilde{H}_k^{[i]} |))^T (\text{rs}(\text{rad}([A^{[i]}]) | \tilde{H}_k^{[i]} |)) \\ &\quad + (\text{rs}(\text{rad}([A^{[i]}]) | \tilde{p}_k^{[i]} |))^T (\text{rs}(\text{rad}([A^{[i]}]) | \tilde{p}_k^{[i]} |)) + (B_\omega^{[i]} H_\omega^{[i]})^T B_\omega^{[i]} H_\omega^{[i]}). \end{aligned} \quad (25)$$

In order to verify the size of output zonotope obtained by means of the observer (13) is smaller, the difference between (28) and (31) is evaluated

$$\begin{aligned} (J_{k+1})^2 - (\tilde{J}_{k+1})^2 &= \text{tr}((L_k^{[i]} C^{[i]} H_k^{[i]})^T L_k^{[i]} C^{[i]} H_k^{[i]} - (\text{mid}([A^{[i]}]) H_k^{[i]})^T L_k^{[i]} C^{[i]} H_k^{[i]} \\ &\quad - (L_k^{[i]} C^{[i]} H_k^{[i]})^T \text{mid}([A^{[i]}]) H_k^{[i]} + (L_k^{[i]} D_v^{[i]} H_v^{[i]})^T L_k^{[i]} D_v^{[i]} H_v^{[i]}). \end{aligned} \quad (26)$$

Considering the observer optimal gain (21), previous equation can be rewritten

$$(J_{k+1})^2 - (\tilde{J}_{k+1})^2 = -\text{tr}(L_k^{[i]} C^{[i]} H_k^{[i]} (H_k^{[i]})^T (C^{[i]})^T (L_k^{[i]})^T) - \text{tr}(L_k^{[i]} Q_v^{[i]} (L_k^{[i]})^T), \quad (27)$$

where $Q_v^{[i]} = D_v^{[i]} H_v^{[i]} (D_v^{[i]} H_v^{[i]})^T$.

Since $L_k^{[i]} C^{[i]} H_k^{[i]} (H_k^{[i]})^T (C^{[i]})^T (L_k^{[i]})^T$ and $L_k^{[i]} Q_v^{[i]} (L_k^{[i]})^T$ are symmetric matrices with positive elements, it follows that

$$(J_{k+1})^2 - (\tilde{J}_{k+1})^2 \leq 0, \quad (28)$$

Therefore, Theorem 2 is proved. ■

In summary, since the size of the output zonotope is reduced by using an observer-based method, the auxiliary input signal designed by the optimal zonotopic observer method will be smaller. The optimal input signal will be obtained by forcing that the intersection of the output zonotopes in the different system modes is empty. The injection of this signal into the system will allow reducing the size of the minimum separable faults.

4 | OPTIMAL AUXILIARY INPUT DESIGN

In this section, an optimal auxiliary input signal is designed by using the output sets determined in previous section. Since the addition of the input signal will affect the system, the input signal is required to be minimized such that small faults could be detected. In this section, the problem of solving the optimal auxiliary input signal design is mainly transformed into the problem of solving the mixed integer quadratic programming (MIQP).

The optimal auxiliary input signal should satisfy

$$\begin{aligned} \min_{u_k} \quad & (u_k)^T R u_k \\ \text{s.t.} \quad & \mathcal{Y}_{k+1}^{[i]} \cap \mathcal{Y}_{k+1}^{[j]} = \emptyset, i \neq j, i, j \in \{0, 1, 2, \dots, q\}. \end{aligned} \quad (29)$$

where R is a positive semidefinite matrix.

According to (19), the output zonotope is given by

$$\begin{aligned} \mathcal{Y}_{k+1}^{[i]} &= \langle p_{y,k+1}^{[i]}, H_{y,k+1}^{[i]} \rangle \\ &= C^{[i]}([A^{[i]}] - L_k^{[i]} C^{[i]}) \mathcal{X}_k^{[i]} \oplus C^{[i]} B^{[i]} u_k \oplus C^{[i]} L_k^{[i]} y_k \oplus C^{[i]} B_\omega^{[i]} \mathcal{W}^{[i]} \oplus (-C^{[i]} L_k^{[i]} D_v^{[i]} \mathcal{V}^{[i]}). \end{aligned} \quad (30)$$

that can be expressed as

$$\mathcal{Y}_{k+1}^{[i]} = \mathcal{M}_k^{[i]} + C^{[i]} B^{[i]} u_k = \langle \bar{p}_{y,k+1}^{[i]} + C^{[i]} B^{[i]} u_k, H_{y,k+1}^{[i]} \rangle, \quad (31)$$

with

$$\mathcal{M}_k^{[i]} = \langle \bar{p}_{y,k+1}^{[i]}, H_{y,k+1}^{[i]} \rangle, \quad (32)$$

where

$$\begin{aligned} \bar{p}_{y,k+1}^{[i]} &= C^{[i]} \text{mid}([A^{[i]}] - L_k^{[i]} C^{[i]}) p_k^{[i]} + L_k^{[i]} y_k, \\ p_{y,k+1}^{[i]} &= \bar{p}_{y,k+1}^{[i]} + C^{[i]} B^{[i]} u_k. \end{aligned} \quad (33)$$

Theorem 3. *The intersection of output zonotopes of the healthy and faulty models is empty*

$$\mathcal{Y}_{k+1}^{[i]} \cap \mathcal{Y}_{k+1}^{[j]} = \emptyset, i \neq j, i, j \in \{0, 1, 2, \dots, q\}. \quad (34)$$

if and only if

$$\Delta^{[ij]} u_k \notin \mathcal{Y}_{m,k}^{[ij]} \quad (35)$$

where $\Delta^{[ij]} = C^{[j]} B^{[j]} - C^{[i]} B^{[i]}$, $\mathcal{Y}_{m,k}^{[ij]} = \mathcal{M}_k^{[i]} - \mathcal{M}_k^{[j]}$.

Proof. Using (38), (40) can be written as

$$\langle \bar{p}_{y,k+1}^{[i]} + C^{[i]}B^{[i]}u_k, H_{y,k+1}^{[i]} \rangle \cap \langle \bar{p}_{y,k+1}^{[j]} + C^{[j]}B^{[j]}u_k, H_{y,k+1}^{[j]} \rangle = \emptyset. \quad (36)$$

According to Lemma 3, if and only if

$$C^{[j]}B^{[j]}u_k - C^{[i]}B^{[i]}u_k \notin \langle \bar{p}_{y,k+1}^{[i]}, H_{y,k+1}^{[i]} \rangle \oplus \langle \bar{p}_{y,k+1}^{[j]}, H_{y,k+1}^{[j]} \rangle = \mathcal{M}_k^{[i]} - \mathcal{M}_k^{[j]}. \quad (37)$$

Theorem 3 is proved. \blacksquare

So, according to Theorem 3, (35) can be rewritten as

$$\begin{aligned} & \min_{u_k} (u_k)^T R u_k \\ & s.t. \quad \Delta^{[ij]}u_k \notin \mathcal{Y}_{m,k}^{[ij]}, i \neq j, i, j \in \{0, 1, 2, \dots, q\}. \end{aligned} \quad (38)$$

Since optimization problem (44) is a nonconvex optimization problem, it is not easy to obtain the optimal solution. So, the optimization problem (44) is reformulated and transformed into a MIQP problem to obtain the effective solution.

To this aim, the zonotope $\mathcal{Y}_{m,k}^{[ij]}$ is defined as

$$\mathcal{Y}_{m,k}^{[ij]} = \langle p_{m,k}^{[ij]}, H_{m,k}^{[ij]} \rangle, \quad (39)$$

where $p_{m,k}^{[ij]} \in \mathbb{R}^{[n_y]}$, $H_{m,k}^{[ij]} \in \mathbb{R}^{n_y \times 2r_y}$. When $H_{m,k}^{[ij]}$ is a row full rank matrix, $\mathcal{Y}_{m,k}^{[ij]}$ is a nonempty set.

Using Definition 1, when $\Delta^{[ij]}u_k \in \mathcal{Y}_{m,k}^{[ij]}$,

$$\Delta^{[ij]}u_k = p_{m,k}^{[ij]} + H_{m,k}^{[ij]}\alpha'^{[ij]}, \quad (40)$$

where $\|\alpha'^{[ij]}\|_\infty \leq 1$. If $\Delta^{[ij]}u_k \notin \mathcal{Y}_{m,k}^{[ij]}$,

$$\Delta^{[ij]}u_k = p_{m,k}^{[ij]} + H_{m,k}^{[ij]}\alpha^{[ij]}, \quad (41)$$

where $\|\alpha^{[ij]}\|_\infty \leq 1 + \varepsilon^{[ij]}$ and $\varepsilon^{[ij]} > 0$.

Therefore, (40) can be rewritten as

$$\begin{aligned} & \min_{u_k} (u_k)^T R u_k \\ & \min_{\varepsilon^{[ij]}, \alpha^{[ij]}} \varepsilon^{[ij]} \\ & s.t. \quad \Delta^{[ij]}u_k = H_{m,k}^{[ij]}\alpha^{[ij]} + p_{m,k}^{[ij]}, \\ & \quad \|\alpha^{[ij]}\|_\infty \leq 1 + \varepsilon^{[ij]}, \\ & \quad \varepsilon^{[ij]} > 0, \quad i \neq j, i, j \in \{0, 1, 2, \dots, q\}. \end{aligned} \quad (42)$$

Note that the feasible set in (40) is an unbounded set due to the constraint $\varepsilon^{[ij]} > 0$ in (48). Therefore, in order to obtain the optimal auxiliary input signal u_k , suppose there is an upper bound $\bar{\varepsilon}^{[ij]}$ and a lower bound $\underline{\varepsilon}^{[ij]}$, that is

$$\underline{\varepsilon}^{[ij]} \leq \varepsilon^{[ij]} \leq \bar{\varepsilon}^{[ij]}. \quad (43)$$

where $\underline{\varepsilon}^{[ij]} > 0$ and $\bar{\varepsilon}^{[ij]}$ are established according to the physical knowledge of the particular system.

Using (49), (48) can be rewritten as the following two-layer optimization problem

$$\begin{aligned}
& \min_{u_k} (u_k)^T R u_k \\
& \min_{\epsilon^{[ij]}, \alpha^{[ij]}} \epsilon^{[ij]} \\
& \text{s.t. } \underline{\epsilon}^{[ij]} \leq \epsilon^{[ij]} \leq \bar{\epsilon}^{[ij]}, \\
& \Delta^{[ij]} u_k = H_{m,k}^{[ij]} \alpha^{[ij]} + p_{m,k}^{[ij]}, \\
& \|\alpha^{[ij]}\|_\infty \leq 1 + \epsilon^{[ij]}, \\
& \epsilon^{[ij]} > 0, \quad i \neq j, i, j \in \{0, 1, 2, \dots, q\}.
\end{aligned} \tag{44}$$

This two-layer optimization problem is not easy to be solved. Using the theorems 3.3.1 and 3.4.1 in the book,³⁵ the two-layer optimization problem in (50) can be transformed into a single-layer optimization problem by constructing a Lagrangian function.

Theorem 4. For system (10) and using the zonotopic observer in Theorem 1, the optimal auxiliary input signal can be obtained by solving the following optimization problem

$$\begin{aligned}
& \min_{u_k} (u_k)^T R u_k \\
& \text{s.t. } \underline{\epsilon}^{[ij]} \leq \epsilon^{[ij]} \leq \bar{\epsilon}^{[ij]}, \\
& \Delta^{[ij]} u_k = H_{m,k}^{[ij]} \alpha^{[ij]} + p_{m,k}^{[ij]}, \\
& \|\alpha^{[ij]}\|_\infty \leq 1 + \epsilon^{[ij]}, \\
& (\mu_1^{[ij]} + \mu_2^{[ij]})^T \mathbf{1} = 1, \\
& \mu_1^{[ij]} - \mu_2^{[ij]} = (H_{m,k}^{[ij]})^T \lambda^{[ij]}, \\
& (\alpha^{[ij]} - 1 - \epsilon_l^{[ij]}) \in [-2(1 + \bar{\epsilon}^{[ij]})(1 - b_{1,l}^{[ij]}), 0], \\
& (\alpha^{[ij]} + 1 + \epsilon_l^{[ij]}) \in [0, 2(1 + \bar{\epsilon}^{[ij]})(1 - b_{2,l}^{[ij]})], \\
& l = 1, 2, \dots, 2r_y, \epsilon^{[ij]} > 0, \quad i \neq j, i, j \in \{0, 1, 2, \dots, q\}.
\end{aligned} \tag{45}$$

where $\lambda^{[ij]}$, $\mu_1^{[ij]}$, and $\mu_2^{[ij]}$ are the Lagrange multipliers, vector $\mathbf{1} = [1 \ 1 \ \dots \ 1] \in \mathbb{R}^{2r_y}$, $b_{1,l}^{[ij]}$ and $b_{2,l}^{[ij]}$ are binary variables. $\mu_1^{[ij]}$ and $\mu_2^{[ij]}$, respectively, satisfy

$$\mu_1^{[ij]} = [\mu_{1,1}^{[ij]} \ \mu_{1,2}^{[ij]} \ \dots \ \mu_{1,2r_y}^{[ij]}]^T \in \mathbb{R}^{2r_y}, \tag{46}$$

and

$$\mu_2^{[ij]} = [\mu_{2,1}^{[ij]} \ \mu_{2,2}^{[ij]} \ \dots \ \mu_{2,2r}^{[ij]}]^T \in \mathbb{R}^{2r_y}, \tag{47}$$

Proof. The Lagrange function for the optimization problem (51) is

$$\begin{aligned}
\mathcal{L} = & \epsilon^{[ij]} + \lambda^{[ij]} (H_{m,k}^{[ij]} \alpha^{[ij]} + p_{m,k}^{[ij]} - \Delta^{[ij]} u_k) + \mu_{1,1}^{[ij]} (-\alpha_1^{[ij]} - 1 - \epsilon^{[ij]}) + \mu_{1,2}^{[ij]} (-\alpha_2^{[ij]} - 1 - \epsilon^{[ij]}) + \dots \\
& + \mu_{2,2r_y}^{[ij]} (-\alpha_{2r_y}^{[ij]} - 1 - \epsilon^{[ij]}) + \mu_{1,1}^{[ij]} (\alpha_1^{[ij]} - 1 - \epsilon^{[ij]}) + \mu_{2,2}^{[ij]} (\alpha_2^{[ij]} - 1 - \epsilon^{[ij]}) + \dots + \mu_{2,2r_y}^{[ij]} (\alpha_{2r_y}^{[ij]} - 1 - \epsilon^{[ij]}) \\
= & \epsilon^{[ij]} + \lambda^{[ij]} (H_{m,k}^{[ij]} \alpha^{[ij]} + p_{m,k}^{[ij]} - \Delta^{[ij]} u_k) - (\mu_1^{[ij]})^T \alpha^{[ij]} - (\mu_1^{[ij]})^T \mathbf{1} - (\mu_1^{[ij]})^T \mathbf{1} \epsilon^{[ij]} \\
& + (\mu_2^{[ij]})^T \alpha^{[ij]} - (\mu_2^{[ij]})^T \mathbf{1} - (\mu_2^{[ij]})^T \mathbf{1} \epsilon^{[ij]}.
\end{aligned} \tag{48}$$

The first-order optimality conditions can be obtained by computing the derivative of \mathcal{L} with respect the decision variables

$$\begin{aligned}
\frac{\partial \mathcal{L}}{\partial \varepsilon^{[ij]}} &= 1 - (\mu_1^{[ij]} + \mu_2^{[ij]})^T \mathbf{1} = 0, \\
\frac{\partial \mathcal{L}}{\partial \varepsilon^{[ij]}} &= (H_{m,k}^{[ij]})^T - \mu_1^{[ij]} + \mu_2^{[ij]} = 0, \\
\mu_{1,l}^{[ij]}(\alpha_l^{[ij]} - 1 - \varepsilon^{[ij]}) &= 0, \\
\mu_{2,l}^{[ij]}(\alpha_l^{[ij]} + 1 + \varepsilon^{[ij]}) &= 0.
\end{aligned} \tag{49}$$

The constraints $\mu_{1,l}^{[ij]}(\alpha_l^{[ij]} - 1 - \varepsilon^{[ij]}) = 0$ and $\mu_{2,l}^{[ij]}(\alpha_l^{[ij]} + 1 + \varepsilon^{[ij]}) = 0$ are reformulated by introducing binary variables $b_1^{[ij]}, b_2^{[ij]} \in \{0, 1\}$ as follows

$$\begin{aligned}
b_{1,l}^{[ij]} = 1 &\Rightarrow \mu_{1,l}^{[ij]}, \text{ free}, \quad (\alpha_l^{[ij]} - 1 - \varepsilon_l^{[ij]}) = 0, \\
b_{1,l}^{[ij]} = 0 &\Rightarrow \mu_{1,l}^{[ij]} = 0, \quad (\alpha_l^{[ij]} - 1 - \varepsilon_l^{[ij]}), \text{ free}, \\
b_{2,l}^{[ij]} = 1 &\Rightarrow \mu_{2,l}^{[ij]}, \text{ free}, \quad (\alpha_l^{[ij]} + 1 + \varepsilon_l^{[ij]}) = 0, \\
b_{2,l}^{[ij]} = 0 &\Rightarrow \mu_{2,l}^{[ij]} = 0, \quad (\alpha_l^{[ij]} + 1 + \varepsilon_l^{[ij]}), \text{ free}.
\end{aligned} \tag{50}$$

Therefore, (56) can be written as

$$\begin{aligned}
\mu_{1,l}^{[ij]}, \mu_{2,l}^{[ij]} &\in [0, 1], \\
(\alpha^{[ij]} - 1 - \varepsilon_l^{[ij]}) &\in [-2(1 + \bar{\delta}^{[ij]}), 0], \\
(\alpha^{[ij]} + 1 + \varepsilon_l^{[ij]}) &\in [0, 2(1 + \bar{\delta}^{[ij]})],
\end{aligned} \tag{51}$$

that after some manipulation can be expressed as the following linear constraints:

$$\begin{aligned}
\mu_{1,l}^{[ij]} &\leq b_{1,l}^{[ij]}, \mu_{2,l}^{[ij]} \leq b_{2,l}^{[ij]}, \\
(\alpha^{[ij]} - 1 - \varepsilon_l^{[ij]}) &\in [-2(1 + \bar{\varepsilon}^{[ij]})(1 - b_{1,l}^{[ij]}), 0], \\
(\alpha^{[ij]} + 1 + \varepsilon_l^{[ij]}) &\in [0, 2(1 + \bar{\varepsilon}^{[ij]})(1 - b_{2,l}^{[ij]})].
\end{aligned} \tag{52}$$

More details of this proof process can be seen in the Scott's work.³⁰ ■

$$\mathcal{V}^{[i]} = \langle 0, H_v^{[i]} \rangle, i = 0, 1, \dots, q;$$

Remark 2. Assume that the system is stable similarly as considered in the Zhai's and Scott's works.^{17,30} Thus, an additional input signal, auxiliary input will not affect the stability of the system.

When the auxiliary input signal is obtained, the logic of active FD is mainly based on determining whether the output of the actual system is faulty, then the problem can be transformed into:

$$\text{Fault detection results} = \begin{cases} 1 & y_k \in \mathcal{Y}_k^{[0]}, \\ -1 & y_k \in \mathcal{Y}_k^{[i]}, \\ 0 & y_k \notin \mathcal{Y}_k^{[0]} \text{ and } y_k \notin \mathcal{Y}_k^{[i]}. \end{cases} \tag{53}$$

where $\mathcal{Y}_k^{[0]}$ and $\mathcal{Y}_k^{[i]}$ correspond to the output zonotopes in healthy and faulty models, respectively. If y_k is inside the healthy output zonotope, we use 1 to represent the fault detection result, which means that the system is healthy operation. If y_k falls into faulty output zonotope, -1 is used to represent that the system is faulty. However, sometimes the system is in the transient state from healthy to faulty, y_k belongs neither to the healthy output zonotope nor the faulty output zonotope at a particular time instant. Consequently, it cannot be decided whether the system is faulty or not, we use 0 to represent this situation.

Remark 3. Assuming that there is a point $x \in \mathbb{R}^n$ and zonotope $\mathcal{X} = p \oplus H\mathbf{B}^r$, where $p \in \mathbb{R}^n$, $H \in \mathbb{R}^{n \times r}$. According to the properties of zonotope, the problem of determining whether a point belongs to a zonotope can be transformed into the following constraints:

$$\begin{cases} p_1 + H_1 & \alpha = x_1, \\ p_2 + H_2 & \alpha = x_2, \\ \vdots & \\ p_n + H_n & \alpha = x_{n_x}, \end{cases} \quad (54)$$

where $\alpha = [\alpha_1 \alpha_2 \dots \alpha_r]^T$. Constraints (60) hold if and only if $\|\alpha_r\| \leq 1$. So, when x satisfies the constraints (60), it means that x belongs to the zonotope \mathcal{X} .

Thus, according to Remark 4, the verification of the fault detection conditions presented in (59) can be implemented by solving the constraint satisfaction problem (60). As a result, the proposed active FD method is summarized in Algorithm 1.

Algorithm 1. Active fault detection based on zonotope for uncertain systems

Given $A^{[i]}(\theta)$, $B^{[i]}$, $C^{[i]}$, $B_\omega^{[i]}$, $D_v^{[i]}$, $\mathcal{W}^{[i]}$ and $\mathcal{V}^{[i]}$, $i = 0, 1, \dots, q$;
 $\mathcal{X}_{k-1}^{[i]} \Leftarrow \mathcal{X}_0^{[i]}$, $y_{k-1} \Leftarrow y_0$;
for $k = 1$ **to** **end do**
 Obtain the optimal observer gain $L_{k-1}^{[i]}$;
 Compute $p_{m,k-1}^{[0i]}$ and $H_{m,k-1}^{[0i]}$ according to (32);
 Obtain u_{k-1} by the Theorem 4, than inject it into the system (10);
 Measure y_k ;
 Compute the healthy output zonotope $\mathcal{Y}_k^{[0]}$ and the faulty output zonotope $\mathcal{Y}_k^{[i]}$ of system, respectively, by using (17);
 if $y_k \in \mathcal{Y}_k^{[0]}$ **then**
 Fault detection results = 1, the system is healthy;
 if $y_k \in \mathcal{Y}_k^{[1]}$ **then**
 Fault detection results = -1, the system is faulty;
 else
 Fault detection results = 0, it cannot be decided whether the system is faulty or not.
 end if
 end if
end for

5 | SIMULATION

The low-frequency linear model of a permanent magnet DC motor³⁰ is used to verify the effectiveness of the proposed method in this article. The expression of the model is as follows

$$\begin{aligned} \begin{bmatrix} \frac{di_m(t)}{dt} \\ \frac{dn_m(t)}{dt} \end{bmatrix} &= \begin{bmatrix} -\frac{R}{L} & -\frac{M_e}{L} \\ \frac{M_t}{J_1} & -\frac{f_r}{J_1} \end{bmatrix} \begin{bmatrix} i_m(t) \\ n_m(t) \end{bmatrix} + \begin{bmatrix} \frac{1}{L} \\ 0 \end{bmatrix} u(t), \\ \begin{bmatrix} y_1(t) \\ y_2(t) \end{bmatrix} &= \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix} \begin{bmatrix} x_1(t) \\ x_2(t) \end{bmatrix}, \end{aligned} \quad (55)$$

where i_m (A), u (V), R (Ω), L (H), M_e (V rad/s), M_t (N m/amp), J_1 (J s²/rad), and f_r (J s/rad) are current, armature voltage, resistance, inductance, back EMF constant, torque constant, motor inertia, and friction coefficient, respectively. The parameters of the model are shown in Table 1.

The torque constant M_t can be obtained from the back EMF constant M_e as follows: $M_t = 1.0005M_e$. In order to operate the motor at the speed to 70.3 ((rad/s)), the control input $u_c = 6$ V is applied.

Model (<i>i</i>)	<i>R</i>	<i>L</i> (10 ⁻³)	<i>M_e</i> (10 ⁻²)	<i>J₁</i> (10 ⁻⁴)	<i>f_r</i> (10 ⁻⁴)
0	1.2030	5.5840	8.1876	1.3528	2.3396
1	1.2030	8.7548	8.1876	1.3528	2.3396

TABLE 1 Model parameters

The Euler method is used to discretize (61). Considering the model uncertainties and after time discretization, the discrete-time linear model is obtained as follows

$$\begin{cases} x_{k+1} = A(\theta)x_k + Bu_k + B_\omega\omega_k, \\ y_k = Cx_k + D_vv_k, \end{cases} \quad (56)$$

where

$$A(\theta) \triangleq [A] = A + \Theta, \quad (57)$$

and $\Theta = \begin{bmatrix} \theta & 0 \\ 0 & \theta \end{bmatrix}$ is uncertain matrix, $|\theta| \leq 0.03$. When the system is in the model $i = 0$, the system is healthy operation

$$A^{[0]} = \begin{bmatrix} 0.286 & -0.043 \\ 1.771 & 0.914 \end{bmatrix}, \quad B^{[0]} = \begin{bmatrix} 0.529 & 0.953 \end{bmatrix}, \quad C^{[0]} = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix}, \quad B_\omega^{[0]} = \begin{bmatrix} -0.0254 & -0.0778 \\ -0.3996 & 0.3026 \end{bmatrix}, \quad D_v^{[0]} = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix}.$$

When a fault occurs, the parameter matrices of the system are

$$A^{[1]} = \begin{bmatrix} 0.459 & -0.033 \\ 2.121 & 0.936 \end{bmatrix}, \quad B^{[1]} = \begin{bmatrix} 0.404 & 0.684 \end{bmatrix}, \quad C^{[1]} = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix}, \quad B_\omega^{[1]} = \begin{bmatrix} -0.0254 & -0.0778 \\ -0.3996 & 0.3026 \end{bmatrix}, \quad D_v^{[1]} = \begin{bmatrix} 1 & 0 \\ 0 & 1 \end{bmatrix}.$$

The simulation results presented in the following are obtained considering that the initial state, measurement noise, and process8 disturbance of the system satisfy the following bounds

$$\begin{aligned} x_0 \in \mathcal{X}_0 &= \left\langle \begin{bmatrix} 0.6 \\ 70 \end{bmatrix} \begin{bmatrix} 0.06 & 0 \\ 0 & 0.6 \end{bmatrix} \right\rangle, \\ v_k \in \mathcal{V} &= \left\langle \begin{bmatrix} 0 \\ 0 \end{bmatrix} \begin{bmatrix} 0.06 & 0 \\ 0 & 0.6 \end{bmatrix} \right\rangle, \quad \mathbf{w}_k \in \mathcal{W} = \langle 0, I_2 \rangle. \end{aligned} \quad (58)$$

Assume that the actual system is operating as follows


$$\text{system} = \begin{cases} \text{healthy} & 0 \leq k < 20, \\ \text{faulty} & 20 \leq k < 40, \\ \text{healthy} & 40 \leq k < 60. \end{cases} \quad (59)$$

Figure 3 shows the output sets of healthy and faulty in case that auxiliary input signal is not used. In this figure, the red zonotopes and the blue zonotope are the output sets of the healthy and the faulty models, respectively. Black circles represent the output of actual system. When the auxiliary input signal is not injected into the system, the output set of the healthy model intersects with the output set of the faulty model. When the actual system belongs to the intersecting part, it is impossible to detect whether the fault has occurred. Therefore, in order to detect faults in the system, a proper auxiliary input signal is needed to separate the healthy output sets from the faulty output sets.

In order to verify the effectiveness of the proposed method, the additional methods are used for comparison.

- Method 7: Considering system parameter uncertainties, auxiliary input signal is generated based on output zonotopes without observers.

FIGURE 3 The output sets of healthy and faulty without auxiliary input signal [Colour figure can be viewed at wileyonlinelibrary.com]



For system (10), it is assumed that the state at sample time k is $\tilde{x}_k^{[i]} \in \tilde{\mathcal{X}}_k^{[i]} = \langle \tilde{p}_k^{[i]}, \tilde{H}_k^{[i]} \rangle$. The state at sample time $k+1$ is

$$\tilde{x}_{k+1}^{[i]} \in \tilde{\mathcal{X}}_{k+1}^{[i]} = \langle \tilde{p}_{k+1}^{[i]}, \tilde{H}_{k+1}^{[i]} \rangle, \quad (60)$$

where

$$\begin{cases} \tilde{p}_{k+1}^{[i]} = \text{mid}([A^{[i]}])\tilde{p}_k^{[i]} + B^{[i]}u_k, \\ \tilde{H}_{k+1}^{[i]} = \begin{bmatrix} \text{mid}([A^{[i]}])\tilde{H}_k^{[i]} & \text{rs}(\text{rad}([A^{[i]}]))|\tilde{H}_k^{[i]}| & \text{rs}(\text{rad}([A^{[i]}]))|\tilde{p}_k^{[i]}| & B_\omega^{[i]}H_\omega^{[i]} \end{bmatrix}. \end{cases} \quad (61)$$

Therefore, the zonotope of output system is

$$\tilde{y}_{k+1}^{[i]} \in \tilde{\mathcal{Y}}_{k+1}^{[i]} = \langle \tilde{p}_{y,k+1}^{[i]}, \tilde{H}_{y,k+1}^{[i]} \rangle, \quad (62)$$

where

$$\begin{cases} \tilde{p}_{y,k+1}^{[i]} = C^{[i]}\tilde{p}_k^{[i]}, \\ \tilde{H}_{y,k+1}^{[i]} = \begin{bmatrix} C^{[i]}\tilde{H}_{k+1}^{[i]} & D_v^{[i]}H_v^{[i]} \end{bmatrix}. \end{cases} \quad (63)$$

- Method 7: Observer-based fault detection method without considering system parameter uncertainties.

Assuming that the state at sample time k is $\tilde{x}_k^{[i]} \in \tilde{\mathcal{X}}_k^{[i]} = \langle \tilde{p}_k^{[i]}, \tilde{H}_k^{[i]} \rangle$. The state at sample time $k+1$ is

$$\tilde{x}_{k+1}^{[i]} \in \tilde{\mathcal{X}}_{k+1}^{[i]} = \langle \tilde{p}_{k+1}^{[i]}, \tilde{H}_{k+1}^{[i]} \rangle, \quad (64)$$

where

$$\begin{cases} \tilde{p}_{k+1}^{[i]} = A^{[i]}\tilde{p}_k^{[i]} + B^{[i]}u_k + L_k^{[i]}y_k \\ \tilde{H}_{k+1}^{[i]} = \begin{bmatrix} (A^{[i]} - L_k^{[i]}C^{[i]})\tilde{H}_k^{[i]} & B_\omega^{[i]}H_\omega^{[i]} & L_k^{[i]}D_v^{[i]}H_v^{[i]} \end{bmatrix} \end{cases} \quad (65)$$

Therefore, the zonotope of output system can be written as

$$\tilde{y}_{k+1}^{[i]} \in \tilde{\mathcal{Y}}_{k+1}^{[i]} = \langle \tilde{p}_{y,k+1}^{[i]}, \tilde{H}_{y,k+1}^{[i]} \rangle, \quad (66)$$

where

$$\begin{cases} \tilde{p}_{y,k+1}^{[i]} = C^{[i]} \tilde{p}_k^{[i]}, \\ \tilde{H}_{y,k+1}^{[i]} = \begin{bmatrix} C^{[i]} \tilde{H}_k^{[i]} & D_v^{[i]} H_v^{[i]} \end{bmatrix}. \end{cases} \quad (67)$$

Figures 4-6 show the size of the generated input signals, the influence of the auxiliary input signal on system, and the size of the output zonotope with the method ①, method ②, and the proposed method, respectively. In Figure 4, the purple dashed line, blue dotted line, and red solid line are the auxiliary input signals obtained by method ①, method ②, and the proposed method, respectively. The amplitudes of auxiliary input signals by method ② and the proposed method are smaller than method ①. In addition, it can be seen that the influence of the input signals based on Method ① is largest then the other two. The size of the output zonotope can be obtained by means of Property 6. According to the idea of active FD, the larger the volume of the output zonotopes, the greater volume of the intersection of the output zonotopes,




FIGURE 4 The auxiliary input signal [Colour figure can be viewed at wileyonlinelibrary.com]




FIGURE 5 The effect of auxiliary input signal on system output [Colour figure can be viewed at wileyonlinelibrary.com]

FIGURE 6 The size of zonotope [Colour figure can be viewed at wileyonlinelibrary.com]





FIGURE 7 The output sets of healthy and faulty obtained by the proposed method model [Colour figure can be viewed at wileyonlinelibrary.com]



so a larger auxiliary input signal is required to separate them. In Figure 6, V_1 and V_2 represent the size of the output zonotopes in healthy and faulty models, respectively.

Figures 7 and 8 show the output sets for the healthy and faulty models after the auxiliary input signal designed with the method proposed is injected into the system from $k = 20$ to $k = 23$ and from $k = 40$ to $k = 43$, respectively. In these figures, the red zonotopes are the output sets of the healthy model, and the blue zonotope are the output sets of faulty model, respectively. Black circles represent the output of the actual system. In Figure 7, the actual system output falls in the output zonotope of the faulty model at $k = 21$. This means that the fault is detected since $k = 21$, because at $k = 20$ the actual output was still in output zonotope of the healthy model. According to (65), the system present the fault from $k = 20$, so there is time delay of one sample time in the fault detection process. Similarly, the output of actual system falls in the output zonotope of the healthy model at $k = 41$, so the system is detected to be in the faulty state at this time.

The comparison of the fault detection results between the proposed method and methods 1 and 7 are shown in Figure 9. These result are obtained by checking the conditions (59) with the method proposed in Remark 2. Since method 1 doesn't consider the system parameter uncertainties, it may generate some wrong fault detection results.




FIGURE 8 The output sets of healthy and faulty model obtained by the proposed method [Colour figure can be viewed at wileyonlinelibrary.com]




FIGURE 9 The result of fault detection [Colour figure can be viewed at wileyonlinelibrary.com]

According to Figures 4 and 9, the auxiliary input signal obtained by the method ① is the smallest, but the detectability of faults is poor. Method ② presents satisfactory detection results, but the auxiliary input signal is big (see Figure 4). Compared with the other two methods, the proposed method has a small auxiliary input signal and can correctly detect the system model. In summary, the proposed method has advantages because of the smaller auxiliary input signals required while presenting satisfactory detection results.

6 | CONCLUSIONS

In this article, an active FD method based on set-membership approach for uncertain discrete-time system is proposed. First, a zonotopic observer is designed with the aim of minimizing the set that bounds the output estimated set. This is achieved by means of a time-varying gain of the observer that is obtained by minimizing the size of the zonotope bounding output sets. Then, a proper auxiliary input signal is designed to separate the output zonotopes of the healthy model from

the output zonotopes of the faulty model. Finally, the input signal is injected into the system to detect small faults. Based on the results obtained using the considered case study, the proposed method reduces the size of the output zonotopes and conservativeness of the auxiliary input signal design process by using zonotopic observers. Since the auxiliary input signal belongs to an external signal, the addition of the auxiliary input signal will have an impact on the system. Therefore, a method for further reducing the conservativeness will be focused on in future research.

ACKNOWLEDGEMENTS

J. Wang is thankful for the grant funded by NSFC (61973023, 61573050) and the Fundamental Research Funds for the Central Universities (No. XK1802-4). M. Zhou is thankful for the grant funded by NSFC (51805021) and Research foundation for talents of NCUT (No.213051360020XN173/017, 110051360020XN092).

ORCID

Jing Wang  <https://orcid.org/0000-0002-6847-8452>

Meng Zhou  <https://orcid.org/0000-0003-4224-3783>

Ye Wang  <https://orcid.org/0000-0003-1395-1676>

Vicenç Puig  <https://orcid.org/0000-0002-6364-6429>

REFERENCES

1. Xu F, Tan J, Wang X, et al. Generalized set-theoretic unknown input observer for LPV systems with application to state estimation and robust fault detection. *Int J Robust Nonlinear Control*. 2017;27:3812-3832.
2. Wang Y, Puig V, Cembrano G. Robust fault estimation based on zonotopic Kalman filter for discrete-time descriptor systems. *Int J Robust Nonlinear Control*. 2018;28(16):5071-5086.
3. Li X, Zhu F. Fault-tolerant control for Markovian jump systems with general uncertain transition rates against simultaneous actuator and sensor faults. *Int J Robust Nonlinear Control*. 2017;27(18):4245-4274.
4. Nikoukhah R, Campbell S, Drake K. An active approach for detection of incipient faults. *Int J Syst Sci*. 2010;41:241-257.
5. Pourasghar M, Puig V, Ocampo-Martinez C. Interval observer versus set-membership approaches for fault detection in uncertain systems using zonotopes. *Int J Robust Nonlinear Control*. 2019;29:2819-2843.
6. Zhou M, Wang Z, Shen Y, Shen M. H_-/H_∞ fault detection observer design in finite-frequency domain for Lipschitz non-linear systems. *IET Control Theory Appl*. 2017;11(14):2361-2369.
7. Zhang Q, Geng S. Dynamic uncertain causality graph applied to dynamic fault diagnoses of large and complex systems. *IEEE Trans Reliab*. 2015;64(3):910-927.
8. Kallas M, Mourot G, Maquin D, Ragot J. Data-driven approach for fault detection and isolation in nonlinear system. *Int J Robust Nonlinear Control*. 2018;32:1569-1590.
9. Cai B, Zhao Y, Liu H, Xie M. A data-driven fault diagnosis methodology in three-phase inverters for PMSM drive systems. *IEEE Trans Power Electron*. 2017;32(7):5590-5600.
10. Šimandl MJ, Punčochář I. Active fault detection and control: unified formulation and optimal design. *Automatica*. 2009;45:2052-2059.
11. Punčochář I, Škach J. A survey of active fault diagnosis methods. *IFAC-PapersOnline*. 2018;51(24):1091-1098.
12. Wang J, Zhang J, Qu B, Wu H, Zhou J. Unified architecture of active fault detection and partial active fault-tolerant control for incipient faults. *IEEE Trans Syst Man Cybernetics Syst*. 2017;47(7):1688-1700.
13. Marseglia GR, Raimondo DM. Active fault diagnosis: a multi-parametric approach. *Automatica*. 2017;79:223-230.
14. Kerestecioglu F, Çetin I. Optimal input design for the detection of changes towards unknown hypotheses. *Int J Syst Sci*. 2004;35(7):435-444.
15. Škach J, Punčochář I, Lewis FL. Optimal active fault diagnosis by temporal-difference learning. Paper presented at: Proceedings of IEEE 55th Conference on Decision and Control; December 12 – 14, 2016; Las Vegas, USA.
16. Garulli A, Vicino A. Set membership localization of mobile robots via angle measurements. *IEEE Trans Robot Autom*. 2001;17(4):450-463.
17. Zhai S, Wang W, Ye H. Auxiliary signal design for active fault detection based on set-membership. *IFAC-PapersOnLine*. 2015;48(21):452-457.
18. Wang J, Wang J, Zhou J. On-line active fault detection based on set-membership ellipsoid and moving window. Paper presented at: Proceedings of IEEE 7th Data Driven Control and Learning Systems Conference; 2018;420-425.
19. Scott JK, Findeisen R, Braatz RD, Raimondo DM. Design of active inputs for set-based fault diagnosis. Paper presented at: Proceedings of American Control Conference; 2013; Washington, DC.
20. Raimondo DM, Marseglia GR, Braatz DR, Scott JK. Closed-loop input design for guaranteed fault diagnosis using set-valued observers. *Automatica*. 2016;74:107-117.
21. Tabatabaeipour SM. Active fault detection and isolation of linear time varying systems: a set-membership approach. *Int J Syst Sci*. 2013;46(11):1917-1933.
22. Campbell SL, Kg H, Nikoukhah R. Auxiliary signal design for rapid multi-model identification using optimization. *Automatica*. 2002;38:1313-1325.
23. Campbell SL, Nikoukhah R. *Auxiliary signal design for failure detection*. Princeton, NJ: Princeton University Press; 2004.

24. Zhou M, Cao Z, Zhou M, Wang J, Wang Z. Zonotopic fault estimation for discrete-time LPV systems with bounded parametric uncertainty. *IEEE Trans Intell Transp Syst.* 2019;21(2):690–700. <https://doi.org/10.1109/TITS.2019.2898853>.
25. Combastel C. Merging Kalman filtering and zonotopic state bounding for robust fault detection under noisy environment. *IFAC-PapersOnLine.* 2015;48(21):289-295.
26. Alamo T, Bravo JM, Camacho EF. Guaranteed state estimation by zonotopes. *Automatica.* 2005;41(6):1035-1043.
27. Le V, Stoica C, Alamo T, Camacho EF, Dumur D. Zonotopic guaranteed state estimation for uncertain systems. *Automatica.* 2013;49:3418-3424.
28. Wang Y, Puig V, Cembrano G. Set-membership approach and Kalman observer based on zonotopes for discrete-time descriptor systems. *Automatica.* 2018;93:435-443.
29. Combastel C. A state bounding observer for uncertain non-linear continuous-time systems based on zonotopes. Paper presented at: Proceedings of the 44th IEEE Conference on Decision and Control; December 12 – 15, 2005;7228-7234; Seville, Spain.
30. Scott JK, Findeisen R, Braatz RD, Raimondo DM. Input design for guaranteed fault diagnosis using zonotopes. *Automatica.* 2014;50(6):1580-1589.
31. Dobkin D, Hershberger J, Kirkpatrick D, Suri S. Computing the intersection-depth of polyhedra. *Algorithmica.* 1998;9:518-533.
32. Pourasghar M, Puig V, Ocampo-Martinez C. Characterisation of interval-observer fault detection and isolation properties using the set-invariance approach. *J Franklin Inst.* 2019.357(3):1853–1886.
33. Wang Y, Wang ZH, Puig V, Cembrano G. Zonotopic set-membership state estimation for discrete-Time descriptor LPV systems. *IEEE Trans Autom Control.* 2019;64(5):2092-2099.
34. Combastel C. Zonotopes and Kalman observers: Gain optimality under distinct uncertainty paradigms and robust convergence. *Automatica.* 2015;55:265-273.
35. Bertsekas DP. *Nonlinear programming.* Athena Scientific: Belmont, MA; 1999.